

Instructions for filter replacement in ventilation units

CASA Smart R3 L



Replacing filters

The ventilation unit's filter should be changed **at least once a year, or twice a year if necessary.**

The filters should be replaced in the spring, before the air is filled with street dust and pollen as well as in the autumn, so that dirt and dust that has collected in the filter does not impair the ventilation.

The filters must be replaced more frequently if there is a great deal of dust in the air in the home or if there are many impurities in the outdoor air.

Only use original Swegon-filters in the unit. This is important, as filters with exactly the same appearance and size can have a completely different pressure loss and filter capacity.

The use of incorrect filters may result in the ventilation unit not working correctly and Swegon cannot be held responsible for any malfunctioning.

Watch the filter replacement videos and study the filter replacement guides for all Swegon CASA ventilation units, and order filters from the link below:

[Filter replacement \(videos\)](#)



[Filter guide \(pdf\)](#)

