



# Installation Detail

If your proposed installation details differ from that shown here, please discuss this with the authority having jurisdiction, referencing this documentation.

Deviation from this drawing requires approval of the relevant authority.

Connecting ductwork omitted for clarity. Ductwork must be independently supported. There must be an appropriate break-away joint between the damper and the connecting ductwork on both sides of the installation.

A minimum of 200mm between fire dampers installed in separate ducts and 75mm between fire damper and construction elements/edges needs to be observed unless otherwise specified in the drawing.



**SCAN ME**

Please refer to the DoP for latest classifications for CE/UKCA compliance and the Installation, Operation and Maintenance Guide

C	ECN2374	MJB	11-09-24
B	ECN2281	JPM	22/06/23
A	Initial Issue	JPM	29/04/22
Rev:	Comments:	By:	Date:

Drawn By: M. Bushell Date: 01/12/2021

Checked By: M. Kimberley Date: 20/08/2024

Approved By: S. Gore Date: 27/08/2024

Description:  
**VERTICAL APPLICATION**  
**SMOKE SHIELD DWFX-F IN**  
**EUROBOND FIREMASTER EXTRA**  
**100mm COMPOSITE WALL**  
Damper Size Range (mm)  
200 x 200 to 1000 x 1000

Reference No:	Sheet	Rev
AAF13396	1 of 1	C

