



BACnet is a registered trademark of ASHRAE. ASHRAE does not endorse, approve or test products for compliance with ASHRAE standards. Compliance of listed products to the requirements of ASHRAE Standard 135 is the responsibility of BACnet International. BTL is a registered trademark of BACnet International.

## BACnet Testing Laboratories Product Listing

*BACnet functionality in each Listed product has been successfully tested at a Recognized BACnet Testing Organization utilizing the industry standard BTL test suite and test policies that were current at the time it was tested. For Listings with multiple products, some products may have less functionality than is indicated by the Listing document. The PICS document provides information on the specific functionality of each product. Note that PICS documents on the BTL Listings site are provided by the manufacturer and are not independently verified by BTL.*

### **Listing Information (BTL-31458)**

Vendor	Listing Status	
Swegon Operations AB Frejgatan 14 53530 Kvänum Sweden	Listed Product	
Test Requirements	BACnet Protocol Revision	Date Tested
Requirements as of February 2024	Revision 19 (135-2016)	September 2025

Product Name	Model Numbers	Version
SuperWISE	BOXER-6404U-A1-1010, BOXER-6750-A1-1010	2

### **Device Profiles**

Profile	Model Numbers
BACnet Building Controller (B-BC)	All models

### **BIBBs Supported**

Data Sharing	ReadProperty-A	DS-RP-A
	ReadProperty-B	DS-RP-B
	ReadPropertyMultiple-A	DS-RPM-A
	ReadPropertyMultiple-B	DS-RPM-B
	WriteProperty-A	DS-WP-A
	WriteProperty-B	DS-WP-B
	WritePropertyMultiple-B	DS-WPM-B
	Change Of Value-B	DS-COV-B
	Change Of Value Unsubscribed-B	DS-COVU-B

Alarm and Event Notification	Notification Internal-B	AE-N-I-B
	Acknowledge-B	AE-ACK-B
	Information-B	AE-INFO-B
	Configurable Recipient Lists-B	AE-CRL-B
Scheduling	Internal-B	SCHED-I-B
	External-B	SCHED-E-B
Trending	Viewing and Modifying Trends Internal-B	T-VMT-I-B
	Automated Trend Retrieval-B	T-ATR-B
Device Management	Dynamic Device Binding-A	DM-DDB-A
	Dynamic Device Binding-B	DM-DDB-B
	Dynamic Object Binding-B	DM-DOB-B
	DeviceCommunicationControl-B	DM-DCC-B
	TimeSynchronization-B	DM-TS-B
	UTCTimeSynchronization-B	DM-UTC-B
	ReinitializeDevice-B	DM-RD-B
	Backup and Restore-B	DM-BR-B
	Restart-B	DM-R-B
	List Manipulation-B	DM-LM-B
	Object Creation and Deletion-B	DM-OCD-B
	Router Configuration-B	NM-RC-B
	BBMD Configuration-B	NM-BBMDC-B
	Foreign Device Registration-A	NM-FDR-A

## Object Type Support

Analog Input	Analog Output	Analog Value
Binary Input	Binary Output	Binary Value
Calendar	Device	Event Enrollment
File	Multi-State Input	Multi-State Output
Multi-State Value	Network Port	Notification Class
Schedule	Structured View	Trend Log

## Data Link Layer Options

Media	Options
BACnet/IP (Annex J)	BBMD BACnet/IP, 'DIX' Ethernet

## Character Set Support

ISO 10646 (UTF-8)