

Installation bottom connection section TCBC GOLD/SILVER C, sizes 004-040

1. General

In cases where both (or all four) downward duct connections are required, the spacer section TCGA with downward duct connection (see the separate installation instruction) and a bottom connection section can be used, see the basic layout diagram.

Duct connections are equipped with a connection frame with predrilled holes for screw connection.

The cover panels on the inspection side are easily removed.

For reasons of safety, duct connections are fitted with grille plates.

In certain cases extra spacer sections may be required to produce a straight unit finish.

Bottom connection sections are available for GOLD/SILVER C RX/PX/CX sizes 004-040.

2. Installation

The bottom connection section is placed as shown in the basic layout diagram below.

For assembly, see the installation instructions for GOLD and SILVER C.

Basic layout diagram



