

## FUNCTIONAL PROFILE:

GOLDen GATE Lonworks FTT-10, TBLZ-3-1-1-41, Version 1.00

GOLD RX/PX/CX/SD, GENERATION E

Applicable to program version 1.10 and newer versions



---

## General

This document describes the profile at the GOLD-LON interface.

The LON interface is a separate communication unit that solely transfers data to and from the control system in the GOLD air handling unit.

This edition of the GOLD-LON interface should be used for monitoring GOLD RX/PX/CX/SD generation E, across a LON bus.

It is not possible to override the physical inputs of the GOLD air handling unit, only monitor them across the LON bus.

The temperature and air flow set points can be adjusted across the LON network. The functions in the GOLD control system can be adjusted, enabled or disabled. The integrated switching clock can also be set to the current time.

The interface is normally equipped with a Transceiver for Twisted Pair Open Topology (TP/FT-10).


This is a ready-to-use module, developed and accepted by Echelon.

The LON software in the interface supports the self-documentation and Wink function and thus helps with installing nodes across a network manager.

The network variables are to SNVT Standard.

The LON Interface can be illustrated as follow:

Figure 1  
Functional profile



---

## Power-Up State

All the input variables have a 0 reading before communication with the GOLD air handling unit has been established.

When communication with the GOLD unit has been in progress for about 60 seconds, all the input variables have been upgraded with the values from the GOLD air handling unit's internal Flash.

This means that the input variables are always upgraded after a power failure and therefore always indicate the current value, as long as the communication is OK:

## LED/Keyed Functions

### **Normal operation:**

The "Module Status" LED will flash green.

The "Serial Status" LED will flash green whenever acknowledged communication with the GOLD takes place.

### **Service:**

The "Service" LED will flash if the node has not been configured. Configuration is normally carried out by a LON manager. While the LON manager is configuring the node, the operator will be requested to depress "servicepin" to identify the node. The node has integrated self-identification and self-description of the parameters.


## Wink Function


This command can be used for identifying the GOLD air handling unit.

The "Serial Status" LEDs green and red flash alternately for 15 seconds while the Wink command is being transmitted to the LON interface.

This input variable can be used for checking whether the LON network is intact up to the LON interface and for identifying a specific air handling unit if several units are connected to the same network.

Figure 2  
Functional profile number 8080  
of LonMark Unit Ventilator object  
details(variables not implemented  
in GOLD are greyed).





NV Index	SNVT No	SNVT Name	SNVT Type	Description	Min	Max	Unit	Default	Misc
<b>Alarm settings</b>									
0	100	nviAlarm_reset	SNVT_switch	Alarm Reset Act Resets all active alarms	0	1		0	
1	101	nvoAlarm_reset		Alarm Reset					
2	104	nviInt_fire_func	SNVT_switch	Int Fire AI Act	0	1		0	
3	105	nvoInt_fire_func		Int Fire AI					
4	106	nviInt_fire_ReFu	SNVT_switch	Int Fire AI Res Func Act 0=manual reset, 1=auto reset	0	1		0	
5	107	nvoInt_fire_ReFu		Int Fire AI Res Func					
6	112	nviExt_fire1_ReF	SNVT_switch	Ext Fire AI1 Res Func Act 0=manual reset, 1=auto reset	0	1		0	
7	113	nvoExt_fire1_ReF		Ext Fire AI1 Res Func					
8	114	nviExt_fire2_ReF	SNVT_switch	Ext Fire AI2 Res Func Act 0=manual reset, 1=auto reset	0	1		0	
9	115	nvoExt_fire2_ReF		Ext Fire AI2 Res Func					
10	120	nviExt_Alr1_ReFu	SNVT_switch	Ext AI1 Res Func Act 0=manual reset, 1=auto reset	0	1		0	
11	121	nvoExt_Alr1_ReFu		Ext AI1 Res Func					
12	122	nviExt_Alr2_ReFu	SNVT_switch	Ext AI2 Res Func Act 0=manual reset, 1=auto reset	0	1		0	
13	123	nvoExt_Alr2_ReFu		Ext AI2 Res Func					
14	128	nviExt_alr1_func	SNVT_switch	Ext AI1 Cond Func Act 0=alarm at closed contact, 1=alarm at open contact	0	1		0	
15	129	nvoExt_alr1_func		Ext AI1 Cond Func					
16	130	nviExt_alr2_func	SNVT_switch	Ext AI2 Cond Func Act 0=alarm at closed contact, 1=alarm at open contact	0	1		0	
17	131	nvoExt_alr2_func		Ext AI2 Cond Func					
<b>Operation level/alarm</b>									
18	200	nvoOP_relay	SNVT_switch	Operating Relay output status	0	1			
19	201	nvoDamper_relay	SNVT_switch	Damper Relay output status	0	1			
20	202	nvoLS_relay	SNVT_switch	Low Spd Low speed operation status	0	1			
21	203	nvoHS_relay	SNVT_switch	High Spd High speed operation status	0	1			
22	204	nvoNH_active	SNVT_switch	Int nightheat	0	1			
23	205	nvoMB_active	SNVT_switch	Morning bst	0	1			
24	206	nvoHB_active	SNVT_switch	Heat bst	0	1			
25	207	nvoCB_active	SNVT_switch	Cooling boost	0	1			
26	208	nvoNC_active	SNVT_switch	Smrnight Cool	0	1			
27	212	nvoA_alarm_relay	SNVT_switch	Alrm A Any alarm with priority class A active	0	1			
28	213	nvoB_alarm_relay	SNVT_switch	Alrm B Any alarm with priority class B active	0	1			
<b>Heat exchange</b>									
29	216	nvoHX_active	SNVT_switch	HX op active HX status	0	1			
30	217	nvoHX_recovery	SNVT_switch	HX recovery active HX cool recovery status	0	1			
31	218	nvoHX_defrost	SNVT_switch	HX defrost active HX defrost status	0	1			

NV Index	SNVT No	SNVT Name	SNVT Type	Description	Min	Max	Unit	Default	Misc
32	221	nvoRHX_rotation	SNVT_switch	R.HX. Rotation Monitor RHX speed monitor status	0	1			
33	226	nvoCHX_relay	SNVT_switch	C.HX. Pump output Relay output status	0	1			
<b>AHU Coils</b>									
34	232	nvoExtRegSeqRe	SNVT_switch	Extra reg seq output Relay output status	0	1			
35	237	nvoHeat_relay	SNVT_switch	Pmp Heat Relay output status	0	1			
36	242	nvoCool_1_relay	SNVT_switch	Cool 1 Relay output status	0	1			
37	243	nvoCool_2_relay	SNVT_switch	Cool 2 Relay output status	0	1			
<b>Pre-heat</b>									
38	250	nvoPreHeat_relay	SNVT_switch	Pre-heat output Relay output status	0	1			
<b>Xzone</b>									
39	255	nvoXzone_heat_re	SNVT_switch	Xzone heat output Relay output status	0	1			
40	262	nvoXzone_cool_r1	SNVT_switch	Xzone cool output 1 Relay output status	0	1			
41	263	nvoXzone_cool_r2	SNVT_switch	Xzone cool output 2 Relay output status	0	1			
<b>AYC</b>									
42	298	nvoAYC_HeatPmpRe	SNVT_switch	AYC heat pmp output Relay output status	0	1			
43	303	nvoAYC_CoolPmpRe	SNVT_switch	AYC cool pmp output Relay output status	0	1			
<b>COOL DX</b>									
44	308	nvoCoolDX1_relay	SNVT_switch	Cool DX 1 Relay output status	0	1			
45	314	nvoCoolDX2_relay	SNVT_switch	Cool DX 2 Relay output status	0	1			
<b>Alarms</b>									
46	399	nvoAlarmOut	SNVT_alarm	Location = "GOLD". Object ID = Alarm number (0-1500). Alarm type = Contains either no alarm or an unspecified alarm. Priority level = alarm priority (No comm.=7, A=1, B=2, Info=3 and none=0). Index to SNVT = Not used. Always set at 0. Value = Not used Always set at 0. Year, month, day = Date when alarm tripped. Alarm limit = Not used. Always set at 0.					
<b>AHU Air flow/duct pressure</b>									
47	401	nvoAHU_type	SNVT_count	AHU type 10=GOLD RX, 11=GOLD PX, 12=GOLD CX, 13=GOLD SD/SA, 14=GOLD SD/EA, 15=GOLD SD/SA+CX, 16=GOLD SD/SA+EA, 17=GOLD SD/SA+EA+CX	0	999			
48	402	nvoAirFlowDir	SNVT_switch	Air flow direction 0=Fan no.2 as SA, 1=Fan no.1 as SA.	0	1			
<b>Air flow regulation</b>									
49	403	nvoSF_flow	SNVT_flow	Sup AF Present supply air flow.	0	20000	l/s		

NV Index	SNVT No	SNVT Name	SNVT Type	Description	Min	Max	Unit	Default	Misc
50	404	nvoSF_flowreg	SNVT_flow	<b>Sup AF reg</b> Present supply air flow regulator set point.	0	20000	l/s		
51	405	nvoEF_flow	SNVT_flow	<b>Ext AF</b> Present extract air flow.	0	20000	l/s		
52	406	nvoEF_flowreg	SNVT_flow	<b>Ext AF reg</b> Present extract air flow regulator set point.	0	20000	l/s		
<b>Pressure regulation</b>									
53	407	nvoSF_pressure	SNVT_press_p	<b>Sup air duct pres</b> Present supply air duct pressure.	0.0	2000.0	Pa		
54	408	nvoSF_press_reg	SNVT_press_p	<b>Sup air duct pres reg</b> Present supply air duct pressure regulator set point.	0.0	2000.0	Pa		
55	409	nvoEF_pressure	SNVT_press_p	<b>Ext air duct pres</b> Present extract air duct pressure.	0.0	2000.0	Pa		
56	410	nvoEF_press_reg	SNVT_press_p	<b>Ext air duct pres reg</b> Present extract air duct pressure regulator set point.	0.0	2000.0	Pa		
<b>Demand regulation</b>									
57	411	nvoDemand_lev	SNVT_lev_percent	<b>In sig air VAV dmnd</b> Present input signal for demand regulation.	0.00	100.00	%		
58	412	nvoDemand_reg	SNVT_lev_percent	<b>VAV dmnd regulator</b> Present demand regulator set point.	0.00	100.00	%		
<b>Air flow pressure sensors</b>									
59	413	nvoSF_fan_press	SNVT_press_p	<b>Sup air pres</b> Present air flow pressure in the supply air fan inlet.	0.0	2000.0	Pa		
60	414	nvoEF_fan_press	SNVT_press_p	<b>Ext air pres</b> Present air flow pressure in the extract air fan inlet.	0.0	2000.0	Pa		
<b>Filters</b>									
61	422	nvoSA_PfilterLev	SNVT_press_p	<b>Sup air prefilt prs drop</b> Present supply air pre-filter pressure drop.	0.0	2000.0	Pa		
62	423	nvoSA_Pfilteralr	SNVT_press_p	<b>Sup air prefilt prs drop alm lev</b> Present supply air pre-filter pressure alarm limit.	0.0	2000.0	Pa		
63	424	nvoEA_PfilterLev	SNVT_press_p	<b>Ext air prefilt prs drop</b> Present extract air pre-filter pressure drop.	0.0	2000.0	Pa		
64	425	nvoEA_Pfilteralr	SNVT_press_p	<b>Ext air prefilt prs drop alm lev</b> Present extract air pre-filter pressure alarm limit.	0.0	2000.0	Pa		
65	426	nvoSA_filterLev	SNVT_press_p	<b>Sup air filt prs drop</b> Present supply air filter pressure drop.	0.0	2000.0	Pa		
66	427	nvoSA_filteralr	SNVT_press_p	<b>Sup air filt prs drop alm lev</b> Present supply air filter pressure alarm limit.	0.0	2000.0	Pa		
67	428	nvoEA_filterLev	SNVT_press_p	<b>Ext air filt prs drop</b> Present extract air filter pressure drop.	0.0	2000.0	Pa		
68	429	nvoEA_filteralr	SNVT_press_p	<b>Ext air filt prs drop alm lev</b> Present extract air filter pressure alarm limit.	0.0	2000.0	Pa		
69	430	nvoSA_EfilterLev	SNVT_press_p	<b>Sup air endfilt prs drop</b> Present supply air end-filter pressure drop.	0.0	2000.0	Pa		
70	431	nvoSA_Efilteralr	SNVT_press_p	<b>Sup air endfilt prs drop alm lev</b> Present supply air end-filter pressure alarm limit.	0.0	2000.0	Pa		
<b>Fans</b>									
71	28	nvoFanSpeed	SNVT_switch	<b>Fan Speed Output</b> Present fan speed level of the supply air fan.	0.00	100.00	%		
72	437	nvoEF_speed	SNVT_switch	<b>Run lvl ext air fan</b> Present fan speed level of the extract air fan.	0.00	100.00	%		
73	438	nvoSF_rpm	SNVT_count	<b>Sup air fan rpm</b> Present fan speed level of the supply air fan.	0	4000	rpm		

NV Index	SNVT No	SNVT Name	SNVT Type	Description	Min	Max	Unit	Default	Misc
74	439	nvoEF_rpm	SNVT_count	<b>Ext air fan rpm</b> Present fan speed level of the extract air fan.	0	4000	rpm		
75	440	nvoSF_voltage	SNVT_volt	<b>Volt sup air fan</b> Present voltage level of the supply air fan.	0	500	V		
76	441	nvoEF_voltage	SNVT_volt	<b>Volt ext air fan</b> Present voltage level of the extract air fan.	0	500	V		
77	442	nvoSF_current	SNVT_amp	<b>Current sup air fan</b> Present current level of the supply air fans. Includes all supply air fans.	0	32.700	A		
78	443	nvoEF_current	SNVT_amp	<b>Current ext air fan</b> Present current level of the extract air fans. Includes all supply air fans.	0	32.700	A		
79	444	nvoSF_power	SNVT_count	<b>Consm lev for sup air fan</b> Present power level of the supply air fans. Includes all supply air fans.	0	45.0	kW		
80	445	nvoEF_power	SNVT_count	<b>Consm lev for ext air fan</b> Present power consumption level of the extract air fans. Includes all extract air fans.	0	45.0	kW		
81	446	nvoSF_KWh	SNVT_count	<b>KWh for sup air fan</b> Total power consumption of the supply air fans. Includes all supply air fans.	0	9999	kWh		
82	447	nvoEF_KWh	SNVT_count	<b>KWh for ext air fan</b> Total power consumption level of the extract air fans. Includes all extract air fans.	0	9999	kWh		
83	448	nvoSF_MWh	SNVT_count	<b>MWh for sup air fan</b> Total power consumption of the supply air fans. Includes all supply air fans.	0	9999	MWh		
84	449	nvoEF_MWh	SNVT_count	<b>MWh for ext air fan</b> Total power consumption level of the extract air fans. Includes all extract air fans.	0	9999	MWh		
85	450	nvoSF_Optime	SNVT_count	<b>Sup air fan op time days</b> Total operation time of the supply air fan presented in days (24h).	0..9999	9999	days		
86	451	nvoEF_Optime	SNVT_count	<b>Ext air fan op time days</b> Total operation time of the extract air fan presented in days (24h).	0..9999	9999	days		
87	454	nvoSF_flow_min	SNVT_flow	<b>Sup AF min</b> Supply air AHU min air flow	0	18000	l/s		
88	455	nvoEF_flow_min	SNVT_flow	<b>Ext AF min</b> Extract air AHU min air flow	0	18000	l/s		
89	456	nvoSF_flow_max	SNVT_flow	<b>Sup AF max</b> Supply air AHU max air flow	0	18000	l/s		
90	457	nvoEF_flow_max	SNVT_flow	<b>Ext AF max</b> Extract air AHU max air flow	0	18000	l/s		
91	462	nvoSFP	SNVT_lev_percent	<b>SFP</b> Calculated SFP level.	0.0	1000.0	kW/m3/s		
<b>AHU Temperature sensors</b>									
92	463	nvoSAtemp	SNVT_temp_p	<b>Sup air temp</b> Present supply air temperature.	-55.00	125.00	°C		
93	464	nvoSA_D_temp	SNVT_temp_p	<b>Supply air-D temp</b> Present supply air density temperature.	-55.00	125.00	°C		
94	465	nvoEAtemp	SNVT_temp_p	<b>Ext air/room temp in unit</b> Present extract air temperature in the unit.	-55.00	125.00	°C		
95	466	nvoEA_D_temp	SNVT_temp_p	<b>Extract air-D temp</b> Present extract air density temperature.	-55.00	125.00	°C		

NV Index	SNVT No	SNVT Name	SNVT Type	Description	Min	Max	Unit	Default	Misc
96	467	nvoEAregr_temp	SNVT_temp_p	<b>Ext air/room temp used for reg</b> Present extract air temperature used for regulation.	-55.00	125.00	°C		
97	472	nvoOUTtemp	SNVT_temp_p	<b>Outd air temp in unit</b> Present outdoor air temperature in the unit.	-55.00	125.00	°C		
98	473	nvoOUTreg_temp	SNVT_temp_p	<b>Outd air temp used for reg</b> Present outdoor air temperature used for regulation.	-55.00	125.00	°C		
99	38	nvoOutdoorTemp	SNVT_temp_p	<b>Outdoor Air Temperature Output</b> Present calculated min, max or average (depending of configuration) temperature of outd. sensor 1-4.	-55.00	125.00	°C		
100	1	nviSpaceTemp	SNVT_temp_p	<b>Space Temperature Input</b> Present calculated min, max or average (depending of configuration) temperature of room sensor 1-4. nviSpaceTemp Not used in present SW version. See also nviRoomTempBMS NV index 392.	-55.00	125.00	°C		
101	21	nvoSpaceTemp	SNVT_temp_p	<b>Space Temperature Input</b>					
<b>AHU Temperature regulation</b>									
102	22	nvoEffectSetpt	SNVT_temp_p	<b>Effective Setpoint Output (sup air)</b> Present supply air temperature regulator set point.	0.00	50.00	°C		
103	487	nvoEAtempset_reg	SNVT_temp_p	<b>Ext air temp regulator</b> Present extract air temperature regulator set point.	0.00	50.00	°C		
104	490	nvoHeatPrimaryRe	SNVT_lev_percent	<b>Heat exchange reg</b> Present operation level of the rotary heat exchanger.	0.00	100.00	%		
105	491	nvoEXreg_Heat	SNVT_lev_percent	<b>Lev extra reg seq heat</b> Present level of extra regulation heat.	0.00	100.00	%		
106	33	nvoHeatSecondary	SNVT_lev_percent	<b>Sec Heat Output</b> Present level of reheat.	0.00	100.00	%		
107	495	nvoReCO2_Heat	SNVT_lev_percent	<b>ReCO2 heat level</b> Present level of ReCO <sub>2</sub> heat.	0.00	100.00	%		
108	496	nvoFanDownReg	SNVT_lev_percent	<b>Lev fan air down reg</b> Present level of fan down regulation.	0.00	100.00	%		
109	497	nvoHeatboost	SNVT_lev_percent	<b>Lev heat boost</b> Present level of heating boost.	0.00	100.00	%		
110	498	nvoEXreg_Cool	SNVT_lev_percent	<b>Lev extra reg seq cool</b> Present level of extra regulation cool.	0.00	100.00	%		
111	34	nvoCoolPrimary	SNVT_lev_percent	<b>Primary Cool Output</b> Present level of cooling.	0.00	100.00	%		
112	502	nvoReCO2_Cool	SNVT_lev_percent	<b>ReCO2 cool level</b> Present level of ReCO <sub>2</sub> heat.	0.00	100.00	%		
113	503	nvoCoolboost	SNVT_lev_percent	<b>Lev cool boost</b> Present level of cooling boost.	0.00	100.00	%		
<b>AHU heat exchange</b>									
114	32	nvoHeatPrimary	SNVT_lev_percent	<b>Prim Heat Output</b> Present speed level of the rotary heat exchanger.	0.00	100.00	%		
115	505	nvoRHX_eff	SNVT_lev_percent	<b>R.HX Efficiency</b> Calculated level of rotary heat exchanger efficiency.	0.00	100.00	%		
116	506	nvoHX_pressure	SNVT_press_p	<b>Press drop rot heat exchr</b> Present pressure drop for the rotary heat exchanger.	0.0	2000.0	Pa		
117	507	nvoHX_pressalr	SNVT_press_p	<b>Press drop alarm lmt rot heat exchr</b> Present pressure drop alarm limit for the rotary heat exchanger.	0.0	2000.0	Pa		

NV Index	SNVT No	SNVT Name	SNVT Type	Description	Min	Max	Unit	Default	Misc
118	506	nvoHX_PurgPress	SNVT_press_p	<b>Press drop rot heat exchr purg</b> Present pressure difference for the rotary heat exchangers purging sector.	0.0	1000.0	Pa		
119	510	nvoHX_Optime	SNVT_count	<b>Heat X op time days</b> Total operation time of the rotary heat exchanger presented in days (24h).	0	9999	Days		
120	516	nvoPHX_bypass_op	SNVT_lev_percent	<b>P.HX bypass output</b> Present level of plate heat exchanger bypass output.	0.00	100.00	%		
121	518	nvoPHX_temp_1	SNVT_temp_p	<b>P.HX Temp 1</b> Present bypass temperature sensor 1 in plate heat exchanger.	-55.00	125.00	°C		
122	519	nvoPHX_temp_2	SNVT_temp_p	<b>P.HX Temp 2</b> Present bypass temperature sensor 2 in plate heat exchanger.	-55.00	125.00	°C		
123	526	nvoCHX_valve_op	SNVT_lev_percent	<b>C.HX Valve output</b> Present level of coil heat exchanger valve output.	0.00	100.00	%		
124	528	nvoCHX_temp	SNVT_temp_p	<b>C.HX Temp</b> Present return water temperature for coil heat exchanger.	-55.00	125.00	°C		
125	529	nvoPCHX_Optime	SNVT_count	<b>P/C.HX op time days</b> Total operation time of the coil heat exchanger presented in days (24h).	0	9999	Days		
126	535	nvoPCHX_humidity	SNVT_lev_percent	<b>P/C.HX Humidity</b> Present level of air-humidity for calculation of bypass/valve limitation.	0.00	100.00	%		
<b>AHU Coils</b>									
127	552	nvoEXregFrostT	SNVT_temp_p	<b>Extra reg seq anti frost temp</b> Present extra regulation anti frost temperature for water heat coil. Value 0=overheat when electric heat is used.	-55.00	125.00	°C		
128	552	nvoFrosttemp	SNVT_temp_p	<b>Anti frost temp</b> Present anti frost temperature for water heat coil. Value 0=overheat when electric heat is used.	-55.00	125.00	°C		
129	558	nvoHeat_Optime	SNVT_count	<b>Reheat op time days</b> Total operation time of re-heat presented in days (24h).	0	9999	Days		
130	563	nvoCoolCoilTemp	SNVT_temp_p	<b>Cool coil water temp</b> Present cool water temperature for water cool coil.	-55.00	125.00	°C		
131	568	nvoCool_Optime	SNVT_count	<b>Cooling op time days</b> Total operation time of cool presented in days (24h).	0	9999	Days		
<b>Xzone temperature sensors</b>									
132	573	nvoXzone_SA_temp	SNVT_temp_p	<b>Xzone SA temp</b> Present supply air temperature.	-55.00	125.00	°C		
133	574	nvoXzone_EA_temp	SNVT_temp_p	<b>Xzone EA temp</b> Present extract air temperature in the unit.	-55.00	125.00	°C		
134	575	nvoXZ_RoomEAtemp	SNVT_temp_p	<b>Xzone EA/Room temp</b> Present extract air temperature used for regulation.	-55.00	125.00	°C		
135	580	nvoXZ_Room_temp	SNVT_temp_p	<b>Xzone Room temp min/max/av</b> Present calculated min, max or average (depending on configuration) temperature of room sensor 1-4.	-55.00	125.00	°C		
<b>Xzone Temperature regulation</b>									
136	585	nvoXZ_SAtemp_reg	SNVT_temp_p	<b>Xzone SA temp reg</b> Present supply air temperature regulator set point.	0.00	50.00	°C		
137	586	nvoXZ_EAtemp_reg	SNVT_temp_p	<b>Xzone EA temp reg</b> Present extract air temperature regulator set point.	0.00	50.00	°C		
138	589	nvoXzoneHeatSec	SNVT_lev_percent	<b>Xzone Sec Heat Output</b>	0.00	100.00	%		
139	592	nvoXzoneCoolPrim	SNVT_lev_percent	<b>Xzone Primary Cool Output</b>	0.00	100.00	%		
<b>Xzone coils</b>									
140	598	nvoXzoneFrosttemp	SNVT_temp_p	<b>Xzone Primary Cool Output</b> Present Xzone heat anti frost temperature for water heat coil. Value 0=Overheat when electric heat is used.	-55.00	125.00	°C		

NV Index	SNVT No	SNVT Name	SNVT Type	Description	Min	Max	Unit	Default	Misc
141	609	nvoXZ_CoolCoil_T	SNVT_temp_p	Xzone Cool coil water temp	-55.00	125.00	°C		
<b>Pre-heat</b>									
142	619	nvoPreHeat_temp	SNVT_temp_p	Pre-heat air temp Present pre-heat temperature.	-55.00	125.00	°C		
143	619	nvoPH_temp_reg	SNVT_temp_p	Pre-heat air temp reg Present pre-heat temperature regulator set point.	-40.00	40.00	°C		
144	621	nvoPreHeat_level	SNVT_lev_percent	Pre-heat level					
145	624	nvoPreHeatFrostT	SNVT_temp_p	Pre-heat anti frost temp Present pre-heat anti frost temperature for water heat coil. Value 0=Overheat when electric heat is used.	-55.00	125.00	°C		
<b>ReCO<sub>2</sub></b>									
146	632	nvoReCO2_IntDamp	SNVT_lev_percent	ReCO <sub>2</sub> internal damper output Present output signal to the recirculation damper.	0.00	100.00	%		
147	634	nvoReCO2_ExtDamp	SNVT_lev_percent	ReCO <sub>2</sub> external damper output Present output signal to the outdoor air damper.	0.00	100.00	%		
148	636	nvoReCO2_OutAirF	SNVT_flow	ReCO <sub>2</sub> outdoor airflow Present outdoor air flow level.	0.0	NV 89	l/s		
149	637	nvoReCO2_OAF_reg	SNVT_flow	ReCO <sub>2</sub> outdoor airflow reg Present outdoor air flow regulator set point.	0.0	NV 89	l/s		
<b>Humidity</b>									
150	643	nvoSA_humidity	SNVT_lev_percent	Supply air-humidity Present level of supply air humidity	0.00	100.00	%RH		
151	644	nvoSA_humidity_t	SNVT_temp_p	Supply air-humidity temp Present temperature inside the supply air humidity sensor.	-40.00	123.00	°C		
152	645	nvoSA_dewpoint	SNVT_temp_p	Supply air-dewpoint Calculated supply air dew point.	-40.00	40.00	°C		
153	646	nvoEA_humidity	SNVT_lev_percent	Extract air-humidity Present level of extract air humidity.	0.00	100.00	%RH		
154	647	nvoEA_humidity_t	SNVT_temp_p	Extract air-humidity temp Present temperature inside the extract air humidity sensor.	-40.00	123.00	°C		
155	648	nvoEA_dewpoint	SNVT_temp_p	Extract air-dewpoint Calculated extract air dew point.	-40.00	40.00	°C		
156	650	nvoSA_dewpoint_r	SNVT_temp_p	Supply air-dewpoint reg Present supply air dew point regulator point.	-40.00	40.00	°C		
157	651	nvoDehum_level	SNVT_lev_percent	Dehumidifying output level Present level of the dehumidifying output.	0.00	100.00	%		
158	653	nvoSA_humidi_r	SNVT_temp_p	Supply air-humidifying reg	0.00	100.00	%RH		
159	654	nvoHumidi_level	SNVT_lev_percent	Humidifying output level Present level of the humidifying output.	0.00	100.00	%		
<b>VOC</b>									
160	665	nvoVOC_level	SNVT_count	VOC level Present level of VOC	450	10000	ppm		
<b>SMART Link</b>									
161	692	nvoSL_WB_WaterA	SNVT_temp_p	SL WB outlet water average	-40.0	176.0	°C		
162	693	nvoSL_WB_ReturnW	SNVT_temp_p	SL WB return water	-40.0	176.0	°C		
163	696	nvoSL_WB_HeatedW	SNVT_temp_p	SL WB heated water	-40.0	176.0	°C		
164	697	nvoSL_WB_CoolW	SNVT_temp_p	SL WB chilled water	-40.0	176.0	°C		
165	718	nvoSL_WB_active	SNVT_switch	SL WB operation					
166	719	nvoSL_WB_CoolM	SNVT_switch	SL WB cool mode					
167	722	nvoSL_DX1_active	SNVT_switch	SL DX1 operation	0	1			
168	723	nvoSL_DX1_CoolM	SNVT_switch	SL DX1 cool mode	0	1			
169	726	nvoSL_DX1_PowerS	SNVT_lev_percent	SL DX1 power level set	0	100.00	%		

NV Index	SNVT No	SNVT Name	SNVT Type	Description	Min	Max	Unit	Default	Misc
170	733	nvoSL_DX2_active	SNVT_switch	<b>SL DX2 operation</b>	0	1			
171	734	nvoSL_DX2_CoolM	SNVT_switch	<b>SL DX2 cool mode</b>	0	1			
172	737	nvoSL_DX2_PowerS	SNVT_lev_percent	<b>SL DX2 power level set</b>	0	100.00	%		
173	744	nvoSL_DX3_active	SNVT_switch	<b>SL DX3 operation</b>	0	1			
174	745	nvoSL_DX3_CoolM	SNVT_switch	<b>SL DX3 cool mode</b>	0	1			
175	748	nvoSL_DX3_PowerS	SNVT_lev_percent	<b>SL DX3 power level set</b>	0	100.00	%		
176	755	nvoSL_DX4_active	SNVT_switch	<b>SL DX4 operation</b>	0	1			
177	756	nvoSL_DX4_CoolM	SNVT_switch	<b>SL DX4 cool mode</b>	0	1			
178	759	nvoSL_DX4_PowerS	SNVT_lev_percent	<b>SL DX4 power level set</b>	0	100.00	%		
<b>AYC</b>									
179	773	nvoAYC_Heat_temp	SNVT_temp_p	<b>AYC heat temp</b> Present heat temperature.	-55.00	125.00	°C		
180	774	nvoAYC_Heat_reg	SNVT_temp_p	<b>AYC heat temp reg</b> Present heat temperature regulator set point.	-55.00	125.00	°C		
181	775	nvoAYC_HeatValve	SNVT_lev_percent	<b>AYC heat valve output</b> Present level of the heat valve output.	0	100.00	%		
182	778	nvoAYC_HeatDeman	SNVT_lev_percent	<b>AYC heat demand</b>	0	100.00	%		1.10
183	786	nvoAYC_Cool_Tmp	SNVT_temp_p	<b>AYC cool temp</b> Present cool temperature.	-55.00	125.00	°C		
184	787	nvoAYC_Cool_Reg	SNVT_temp_p	<b>AYC cool temp reg</b> Present cool temperature regulator set point.	-55.00	125.00	°C		
185	788	nvoAYC_CoolValve	SNVT_lev_percent	<b>AYC cool valve output</b> Present cool of the heat valve output.	0	100.00	%		
186	791	nvoAYC_CoolDeman	SNVT_lev_percent	<b>AYC cool demand</b>	0	100.00	%		1.10
<b>Software</b>									
187	969	nvoIQlogicVer	SNVT_count	<b>IQlogic software ver</b> Present controller software version	0.00	99.00			

NV Index	SNVT No	SNVT Name	SNVT Type	Description	Min	Max	Unit	Default	Misc
<b>Operation level</b>									
188	991	nvoOperationLev	SNVT_count	<b>Operation level</b> 0=Fan not available 1=Alarm stop 2=Manual total stop (on hand terminal) 3=External total stop (digital input) 4=Communication total stop 5=Communication normal stop 6=Communication extended normal stop 7=Time channel total stop 8=Time channel normal stop 9=Time channel extended normal stop 10=Low speed=normal stop 11=SA Fan starting up 12=Fan regulation blocked 13=ReCO2 100% recirculation 14=Morning boost stop 15=Intermittent night heat stop 16=After cooling electric heater 17=COOL DX switch off delay 18=Damper switch off delay 19=Manual low speed (on hand terminal) 20=External low speed (digital input) 21=Extended external low speed 22=Communication low speed 23=Time channel low speed 24=Morning boost low speed 25=Intermittent night heat low speed 26=Manual high speed (on hand terminal) 27=External high speed (digital input) 28=Extended external high speed 29=Communication high speed 30=Time channel high speed 31=Summer night cooling high speed 32=Filter calibration 33=RHX Defrost calibration 34=ReCO2 calibration 35=AHU start up 36=Re-heat ramp down 37=HX ramp down 38=Air adjustment	0	100			

NV Index	SNVT No	SNVT Name	SNVT Type	Description	Min	Max	Unit	Default	Misc
<b>Alarms</b>									
189	1003	nvoTriggAlarm1	SNVT_count	<b>Triggered alarm1</b> ((Alarm group - 1) x 15) + alarm number in group=Triggered alarm number. Zero if no triggered alarm.	0	1500			
190	1004	nvoTriggAlarm2	SNVT_count	<b>Triggered alarm2</b>	0	1500			
191	1005	nvoTriggAlarm3	SNVT_count	<b>Triggered alarm3</b>	0	1500			
192	1006	nvoTriggAlarm4	SNVT_count	<b>Triggered alarm4</b>	0	1500			
193	1007	nvoTriggAlarm5	SNVT_count	<b>Triggered alarm5</b>	0	1500			
194	1008	nvoTriggAlarm6	SNVT_count	<b>Triggered alarm6</b>	0	1500			
195	1009	nvoTriggAlarm7	SNVT_count	<b>Triggered alarm7</b>	0	1500			
196	1010	nvoTriggAlarm8	SNVT_count	<b>Triggered alarm8</b>	0	1500			
197	1011	nvoTriggAlarm9	SNVT_count	<b>Triggered alarm9</b>	0	1500			
198	1012	nvoTriggAlarm10	SNVT_count	<b>Triggered alarm10</b>	0	1500			
<b>Time schedule</b>									
199	1054	nvoCurrentAction	SNVT_count	<b>Time schedule action</b> 1=Total stop, 2=Low speed, 3=High speed, 4=Normal stop, 5=Extended normal stop	1	5			
200	1056	nvoException1_A	SNVT_switch	<b>Exception 1 active</b> 0=Inactive, 1=Active	0	1			
201	1057	nvoException2_A	SNVT_switch	<b>Exception 2 active</b> 0=Inactive, 1=Active	0	1			
202	1058	nvoCalendar1_A	SNVT_switch	<b>Calendar 1 active</b> 0=Inactive, 1=Active	0	1			
203	1059	nvoCalendar2_A	SNVT_switch	<b>Calendar 2 active</b> 0=Inactive, 1=Active	0	1			
<b>AHU fan regulation</b>									
204	1100	nviSFregmode	SNVT_count	<b>SA Fan reg mode</b> Setting of regulation type for the supply air fan. 0=Air flow reg. 1=Pressure reg. 2=Demand reg. 3=Slave controlled by EA fan	0	3		0	
205	1101	nvoSFregmode	SNVT_count	<b>SA Fan reg mode</b>					
206	1102	nviEFregmode	SNVT_count	<b>EA Fan reg mode</b> Setting of regulation type for the extract air fan. 0=Air flow reg. 1=Pressure reg. 2=Demand reg. 3=Slave controlled by SA fan	0	3		0	
207	1103	nvoEFregmode	SNVT_count	<b>EA Fan reg mode</b>					
<b>Air flow regulation</b>									
208	1104	nviSF_LSflow	SNVT_flow	<b>Sup air flow lw spd</b> Supply air flow set point for the unit when running in low speed operation.	0	NV 213	l/s		
209	1105	nvoSF_LSflow	SNVT_flow	<b>Sup air flow lw spd</b>					
210	1106	nviEF_LSflow	SNVT_flow	<b>Ext AF lw spd</b> Extract air flow set point for the unit when running in low speed operation.	0	NV 215	l/s		
211	1107	nvoEF_LSflow	SNVT_flow	<b>Ext AF lw spd</b>					
212	1108	nviSF_HSflow	SNVT_flow	<b>Sup air flow high spd</b> Supply air flow set point for the unit when running in high speed operation.	NV 209	NV 217	l/s		
213	1109	nvoSF_HSflow	SNVT_flow	<b>Sup air flow high spd</b>					

NV Index	SNVT No	SNVT Name	SNVT Type	Description	Min	Max	Unit	Default	Misc
214	1110	nviEF_HSflow	SNVT_flow	<b>Ext AF high spd</b> Extract air flow set point for the unit when running in high speed operation.	NV 211	NV 219	l/s		
215	1111	nvoEF_HSflow	SNVT_flow	<b>Ext AF high spd</b>					
216	1112	nviSF_MaxflowBo	SNVT_flow	<b>SA Max spd AF Boost</b> Supply air flow max. limit for the unit when the low/high speed operation set point is altered by boosting function etc.	NV 213	NV 89	l/s		
217	1113	nvoSF_MaxflowBo	SNVT_flow	<b>SA Max spd AF Boost</b>					
218	1114	nviEF_MaxflowBo	SNVT_flow	<b>EA Max spd AF Boost</b> Extract air flow max. limit for the unit when the low/high speed operation set point is altered by boosting function etc.	NV 215	NV 90	l/s		
219	1115	nvoEF_MaxflowBo	SNVT_flow	<b>EA Max spd AF Boost</b>					
220	1116	nviSF_FlowZone	SNVT_lev_percent	<b>SA AF reg zone</b> Supply air flow regulation zone setting in % of the present air flow set point that the regulator is allowed to work within.	1.00	10.00	%	7.50	
221	1117	nvoSF_FlowZone	SNVT_lev_percent	<b>SA AF reg zone</b>					
222	1118	nviEF_FlowZone	SNVT_lev_percent	<b>EA AF reg zone</b> Extract air flow regulation zone setting in % of the present air flow set point that the regulator is allowed to work within.	1.00	10.00	%	7.50	
223	1119	nvoEF_FlowZone	SNVT_lev_percent	<b>EA AF reg zone</b>					
224	1120	nviSF_I-time	SNVT_time_sec	<b>SA AF I-time</b> Supply air flow regulator affection setting.	1	1800	s	30	
225	1121	nvoSF_I-time	SNVT_time_sec	<b>SA AF I-time</b>					
226	1122	nviEF_I-time	SNVT_time_sec	<b>EA AF I-time</b> Extract air flow regulator affection setting.	1	1800	s	30	
227	1123	nvoEF_I-time	SNVT_time_sec	<b>EA AF I-time</b>					
<b>Pressure regulation</b>									
228	1136	nviSF_LSpresure	SNVT_press_p	<b>SA Low spd pres</b> Supply air duct pressure set point for the unit when running in low speed operation.	0.0	NV 233	Pa		
229	1137	nvoSF_LSpresure	SNVT_press_p	<b>SA Low spd pres</b>					
230	1138	nviEF_LSpresure	SNVT_press_p	<b>EA Low spd pres</b> Extract air duct pressure set point for the unit when running in low speed operation.	0.0	NV 235	Pa		
231	1139	nvoEF_LSpresure	SNVT_press_p	<b>EA Low spd pres</b>					
232	1140	nviSF_HSpresure	SNVT_press_p	<b>SA High spd pres</b> Supply air duct pressure for the unit when running in high speed operation.	NV 229	NV 237	Pa		
233	1141	nvoSF_HSpresure	SNVT_press_p	<b>SA High spd pres</b>					
234	1142	nviEF_HSpresure	SNVT_press_p	<b>EA High spd pres</b> Extract air duct pressure set point for the unit when running in high speed operation.	NV 231	NV 239	Pa		
235	1143	nvoEF_HSpresure	SNVT_press_p	<b>EA High spd pres</b>					
236	1144	nviSF_Maxpress	SNVT_press_p	<b>SA Max spd pres</b> Supply air duct pressure max. limit for the unit when the low/high speed operation set point is altered by boosting function etc.	NV 233	750.0	Pa		
237	1145	nvoSF_Maxpress	SNVT_press_p	<b>SA Max spd pres</b>					
238	1146	nviEF_Maxpress	SNVT_press_p	<b>EA Max spd pres</b> Extract air duct pressure max. limit for the unit when the low/high speed operation set point is altered by boosting function etc.	NV 235	750.0	Pa		
239	1147	nvoEF_Maxpress	SNVT_press_p	<b>EA Max spd pres</b>					

NV Index	SNVT No	SNVT Name	SNVT Type	Description	Min	Max	Unit	Default	Misc
240	1148	nviSF_Maxspeed	SNVT_lev_percent	<b>SA Max spd output sig</b> Max. limit for the supply air fan speed when running in pressure regulation mode.	0	100.00	%		
241	1149	nvoSF_Maxspeed	SNVT_lev_percent	<b>SA Max spd output sig</b>					
242	1150	nviEF_Maxspeed	SNVT_lev_percent	<b>EA Max spd output sig</b> Max. limit for the extract air fan speed when running in pressure regulation mode.	0	100.00	%		
243	1151	nvoEF_Maxspeed	SNVT_lev_percent	<b>EA Max spd output sig</b>					
244	1152	nviSF_PressZone	SNVT_lev_percent	<b>SA Pres reg zone</b> Supply air pressure regulation zone setting in % of the present duct pressure set point that the regulator is allowed to work within.	0	10.00	%	7.50	
245	1153	nvoSF_PressZone	SNVT_lev_percent	<b>SA Pres reg zone</b>					
246	1154	nviEF_PressZone	SNVT_lev_percent	<b>EA Pres reg zone</b> Extract air pressure regulation zone setting in % of the present duct pressure set point that the regulator is allowed to work within.	0	10.00	%	7.50	
247	1155	nvoEF_PressZone	SNVT_lev_percent	<b>EA Pres reg zone</b>					
248	1156	nviSF_Press_I-t	SNVT_time_sec	<b>SA Pres I-time</b> Supply air pressure regulator affection setting.	0	1800	s	30	
249	1157	nvoSF_Press_I-t	SNVT_time_sec	<b>SA Pres I-time</b>					
250	1158	nviEF_Press_I-t	SNVT_time_sec	<b>EA Pres I-time</b> Extract air pressure regulator affection setting.	0	1800	s	30	
251	1159	nvoEF_Press_I-t	SNVT_time_sec	<b>EA Pres I-time</b>					
<b>Demand regulation</b>									
252	1172	nviLS_demand	SNVT_lev_percent	<b>Low spd dmnd</b> Set point for the 0..10V input signal for the unit when running in low speed operation.	0.00	100.00	%	50.00	
253	1173	nvoLS_demand	SNVT_lev_percent	<b>Low spd dmnd</b>					
254	1174	nviHS_demand	SNVT_lev_percent	<b>High spd dmnd</b> Set point for the 0..10V input signal for the unit when running in high speed operation.	10.00	100.00	%	25.00	
255	1175	nvoHS_demand	SNVT_lev_percent	<b>High spd dmnd</b>					
256	1176	nviSF_Minflow	SNVT_flow	<b>SA Min spd AF</b> Supply air flow min. limit for the unit when the low/high speed operation set point is altered when running in fan regulation mode demand.	NV 87	NV 261	l/s		
257	1177	nvoSF_Minflow	SNVT_flow	<b>SA Min spd AF</b>					
258	1178	nviEF_Minflow	SNVT_flow	<b>EA Min spd AF</b> Extract air flow min. limit for the unit when the low/high speed operation set point is altered when running in fan regulation mode demand.	NV 88	NV 263	l/s		
259	1179	nvoEF_Minflow	SNVT_flow	<b>EA Min spd AF</b>					
260	1180	nviSF_MaxflowDe	SNVT_flow	<b>SA Max spd AF demand</b> Supply air flow max limit for the unit when the low/high speed operation set point is altered when running in fan regulation mode demand.	NV 257	NV 89	l/s		
261	1181	nvoSF_MaxflowDe	SNVT_flow	<b>SA Max spd AF demand</b>					
262	1182	nviEF_MaxflowDe	SNVT_flow	<b>EA Max spd AF demand</b> Extract air flow max. limit for the unit when the low/high speed operation set point is altered when running in fan regulation mode demand.	NV 259	NV 90	l/s		
263	1183	nvoEF_MaxflowDe	SNVT_flow	<b>EA Max spd AF demand</b>					
264	1184	nviDemand_P-b	SNVT_lev_percent	<b>Dmnd P-band</b> Supply air demand regulator P-band setting.	1.00	100.00	%	40.00	
265	1185	nvoDemand_P-b	SNVT_lev_percent	<b>Dmnd P-band</b>					
266	1186	nviDemand_I-t	SNVT_time_sec	<b>Dmnd I-time</b> Supply air demand regulator affection setting.	1	1800	s	1200	

NV Index	SNVT No	SNVT Name	SNVT Type	Description	Min	Max	Unit	Default	Misc
267	1187	nvoDemand_I-t	SNVT_time_sec	Dmnd I-time					
Slave controlled regulation									
268	1198	nviSlaveOffFact	SNVT_lev_percent	Slave offset factor	50.00	200.00	%	0.00	
269	1199	nvoSlaveOffFact	SNVT_lev_percent	Slave offset factor					

NV Index	SNVT No	SNVT Name	SNVT Type	Description	Min	Max	Unit	Default	Misc
Fans OA temp compensation									
270	1204	nviOutCmpTempFu	SNVT_count	Outd Temp Cmp func 0=Inactive, 1=Active at low speed, 2=Active at high speed, 3=Active at low and high speed.	0	3		0	
271	1205	nvoOutCmpTempFu	SNVT_count	Outd Temp Cmp func					
272	1206	nviOutCmpTempX1	SNVT_temp_p	Outd Temp Cmp X1	-50.00	NV 275	°C	-20.00	
273	1207	nvoOutCmpTempX1	SNVT_temp_p	Outd Temp Cmp X1					
274	1208	nviOutCmpTempX2	SNVT_temp_p	Outd Temp Cmp X2	NV 273	NV 277	°C	-10.00	
275	1209	nvoOutCmpTempX2	SNVT_temp_p	Outd Temp Cmp X2					
276	1210	nviOutCmpTempX3	SNVT_temp_p	Outd Temp Cmp X3	NV 275	NV 279	°C	10.00	
277	1211	nvoOutCmpTempX3	SNVT_temp_p	Outd Temp Cmp X3					
278	1212	nviOutCmpTempX4	SNVT_temp_p	Outd Temp Cmp X4	NV 277	50.00	°C	20.00	
279	1213	nvoOutCmpTempX4	SNVT_temp_p	Outd Temp Cmp X4					
280	1214	nviOutCmpFlwY1SA	SNVT_flow	Outd Temp Cmp Y1 SA Flow	NV 87	NV 89	l/s		
281	1215	nvoOutCmpFlwY1SA	SNVT_flow	Outd Temp Cmp Y1 SA Flow					
282	1216	nviOutCmpFlwY2SA	SNVT_flow	Outd Temp Cmp Y2 SA Flow	NV 87	NV 89	l/s		
283	1217	nvoOutCmpFlwY2SA	SNVT_flow	Outd Temp Cmp Y2 SA Flow					
284	1218	nviOutCmpFlwY3SA	SNVT_flow	Outd Temp Cmp Y3 SA Flow	NV 87	NV 89	l/s		
285	1219	nvoOutCmpFlwY3SA	SNVT_flow	Outd Temp Cmp Y3 SA Flow					
286	1220	nviOutCmpFlwY4SA	SNVT_flow	Outd Temp Cmp Y4 SA Flow	NV 87	NV 89	l/s		
287	1221	nvoOutCmpFlwY4SA	SNVT_flow	Outd Temp Cmp Y4 SA Flow					
288	1222	nviOutCmpFlwY1EA	SNVT_flow	Outd Temp Cmp Y1 EA Flow	NV 88	NV 90	l/s		
289	1223	nvoOutCmpFlwY1EA	SNVT_flow	Outd Temp Cmp Y1 EA Flow					
290	1224	nviOutCmpFlwY2EA	SNVT_flow	Outd Temp Cmp Y2 EA Flow	NV 88	NV 90	l/s		
291	1225	nvoOutCmpFlwY2EA	SNVT_flow	Outd Temp Cmp Y2 EA Flow					
292	1226	nviOutCmpFlwY3EA	SNVT_flow	Outd Temp Cmp Y3 EA Flow	NV 88	NV 90	l/s		
293	1227	nvoOutCmpFlwY3EA	SNVT_flow	Outd Temp Cmp Y3 EA Flow					
294	1228	nviOutCmpFlwY4EA	SNVT_flow	Outd Temp Cmp Y4 EA Flow	NV 88	NV 90	l/s		
295	1229	nvoOutCmpFlwY4EA	SNVT_flow	Outd Temp Cmp Y4 EA Flow					
296	1230	nviOutCmpPrsY1SA	SNVT_press_p	Outd Temp Cmp Y1 SA Press	20.0	750.0	Pa	100.0	
297	1231	nvoOutCmpPrsY1SA	SNVT_press_p	Outd Temp Cmp Y1 SA Press					
298	1232	nviOutCmpPrsY2SA	SNVT_press_p	Outd Temp Cmp Y2 SA Press	20.0	750.0	Pa	100.0	
299	1233	nvoOutCmpPrsY2SA	SNVT_press_p	Outd Temp Cmp Y2 SA Press					
300	1234	nviOutCmpPrsY3SA	SNVT_press_p	Outd Temp Cmp Y3 SA Press	20.0	750.0	Pa	100.0	
301	1235	nvoOutCmpPrsY3SA	SNVT_press_p	Outd Temp Cmp Y3 SA Press					
302	1236	nviOutCmpPrsY4SA	SNVT_press_p	Outd Temp Cmp Y4 SA Press	20.0	750.0	Pa	100.0	
303	1237	nvoOutCmpPrsY4SA	SNVT_press_p	Outd Temp Cmp Y4 SA Press					
304	1238	nviOutCmpPrsY1EA	SNVT_press_p	Outd Temp Cmp Y1 EA Press	20.0	750.0	Pa	100.0	
305	1239	nvoOutCmpPrsY1EA	SNVT_press_p	Outd Temp Cmp Y1 EA Press					
306	1240	nviOutCmpPrsY2EA	SNVT_press_p	Outd Temp Cmp Y2 EA Press	20.0	750.0	Pa	100.0	
307	1241	nvoOutCmpPrsY2EA	SNVT_press_p	Outd Temp Cmp Y2 EA Press					
308	1242	nviOutCmpPrsY3EA	SNVT_press_p	Outd Temp Cmp Y3 EA Press	20.0	750.0	Pa	100.0	
309	1243	nvoOutCmpPrsY3EA	SNVT_press_p	Outd Temp Cmp Y3 EA Press					
310	1244	nviOutCmpPrsY4EA	SNVT_press_p	Outd Temp Cmp Y4 EA Press	20.0	750.0	Pa	100.0	
311	1245	nvoOutCmpPrsY4EA	SNVT_press_p	Outd Temp Cmp Y4 EA Press					
Fans down regulation									
312	1254	nviDownRegFunc	SNVT_count	Fans down reg func 0=Inactive, 1=SA, 2=SA and EA	0	2		1	
313	1255	nvoDownRegFunc	SNVT_count	Fans down reg func					
314	1256	nviDownReq_NZ	SNVT_temp_p	Fans down reg ntral zone	0.00	10.00	K	0.00	

NV Index	SNVT No	SNVT Name	SNVT Type	Description	Min	Max	Unit	Default	Misc
315	1257	nvoDownReg_NZ	SNVT_temp_p	Fans down reg ntrl zone					
316	1258	nviDownReg_P-b	SNVT_temp_p	Fans down reg P-band	1.00	10.00	K	5.00	
317	1259	nvoDownReg_P-b	SNVT_temp_p	Fans down reg P-band					
318	1260	nviDownReg_I-t	SNVT_time_sec	Fans down reg I-time	1	1800	s	30	
319	1261	nvoDownReg_I-t	SNVT_time_sec	Fans down reg I-time					
AHU Temperature regulation									
320	1328	nviTempregmode	SNVT_count	Temp reg mode 1=ERS-1, 2=ERS-2, 3=SA, 4=EA, 5=ORS, 6=ORE	1	6		3	
321	1329	nvoTempregmode	SNVT_count	Temp reg mode					
ERS-1 reg.									
322	1332	nviERS1step	SNVT_count	ERS 1 Step Curve setting according to the diagram for ERS 1.	1	4		2	
323	1333	nvoERS1step	SNVT_count	ERS 1 Step					
324	1334	nviERS1diff	SNVT_temp_p	SA temp diff set ERS 1 Supply air temp difference setting according to the diagram for ERS 1.	1.00	7.00	K	2.00	
325	1335	nvoERS1diff	SNVT_temp_p	SA temp diff set ERS 1					
326	1336	nviERS1brkpnt	SNVT_temp_p	ERS 1 Brkpnt Breakpoint temp setting according to the diagram for ERS 1.	12.00	26.00	°C	22.00	
327	1337	nvoERS1brkpnt	SNVT_temp_p	ERS 1 Brkpnt					
ERS-2 reg.									
328	1342	nviERS2_X1	SNVT_temp_p	ERS 2 Brkpnt_X1 Breakpoint X1 setting according to the diagram for ERS 2.	10.00	NV 331	°C	15.00	
329	1343	nvoERS2_X1	SNVT_temp_p	ERS 2 Brkpnt_X1					
330	1344	nviERS2_X2	SNVT_temp_p	ERS 2 Brkpnt_X2 Breakpoint X2 setting according to the diagram for ERS 2.	NV 329	NV 333	°C	20.00	
331	1345	nvoERS2_X2	SNVT_temp_p	ERS 2 Brkpnt_X2					
332	1346	nviERS2_X3	SNVT_temp_p	ERS 2 Brkpnt_X3 Breakpoint X3 setting according to the diagram for ERS 2.	NV 331	NV 335	°C	22.00	
333	1347	nvoERS2_X3	SNVT_temp_p	ERS 2 Brkpnt_X3					
334	1348	nviERS2_X4	SNVT_temp_p	ERS 2 Brkpnt_X4 Breakpoint X4 setting according to the diagram for ERS 2.	NV 333	40.00	°C	24.00	
335	1349	nvoERS2_X4	SNVT_temp_p	ERS 2 Brkpnt_X4					
336	1350	nviERS2_Y1	SNVT_temp_p	ERS 2 Brkpnt_Y1 Breakpoint Y1 setting according to the diagram for ERS 2.	10.00	40.00	°C	20.00	
337	1351	nvoERS2_Y1	SNVT_temp_p	ERS 2 Brkpnt_Y1					
338	1352	nviERS2_Y2	SNVT_temp_p	ERS 2 Brkpnt_Y2 Breakpoint Y2 setting according to the diagram for ERS 2.	10.00	40.00	°C	18.00	
339	1353	nvoERS2_Y2	SNVT_temp_p	ERS 2 Brkpnt_Y2					
340	1354	nviERS2_Y3	SNVT_temp_p	ERS 2 Brkpnt_Y3 Breakpoint Y3 setting according to the diagram for ERS 2.	10.00	40.00	°C	14.00	
341	1355	nvoERS2_Y3	SNVT_temp_p	ERS 2 Brkpnt_Y3					
342	1356	nviERS2_Y4	SNVT_temp_p	ERS 2 Brkpnt_Y4 Breakpoint Y4 setting according to the diagram for ERS 2.	10.00	40.00	°C	12.00	
343	1357	nvoERS2_Y4	SNVT_temp_p	ERS 2 Brkpnt_Y4					
SA Reg.									
344	2	nviSetpoint	SNVT_temp_p	Temp stpnt Input (absolute) Supply air temperature setting, for supply air temp regulation mode.	10.00	40.00	°C	21.00	
345	1363	nvoSetpoint	SNVT_temp_p	Temp stpnt (absolute)					

NV Index	SNVT No	SNVT Name	SNVT Type	Description	Min	Max	Unit	Default	Misc
<b>EA Reg.</b>									
346	1368	nviEAtempset	SNVT_temp_p	<b>EA Temp</b> Extract air/room temperature setting, for Extract air/room temp regulation mode.	10.00	40.00	°C	21.00	
347	1369	nvoEAtempset	SNVT_temp_p	<b>EA Temp</b>					
348	1370	nviMinSAtemp	SNVT_temp_p	<b>SA Min temp</b> Supply air min. set point during EA/room regulation mode.	8.00	20.00	°C	16.00	
349	1371	nvoMinSAtemp	SNVT_temp_p	<b>SA Min temp</b>					
350	1372	nviMaxSAtemp	SNVT_temp_p	<b>SA Max temp</b> Supply air max. set point during EA/room regulation mode.	16.00	50.00	°C	28.00	
351	1373	nvoMaxSAtemp	SNVT_temp_p	<b>SA Max temp</b>					
352	1374	nviEA_Reg_P-b	SNVT_temp_p	<b>EA reg P-band</b>	1.00	10.00	K	5.00	
353	1375	nvoEA_Reg_P-b	SNVT_temp_p	<b>EA reg P-band</b>					
354	1376	nviEA_Reg_I-t	SNVT_time_sec	<b>EA reg I-time</b>	1	1800	s	30	
355	1377	nvoEA_Reg_I-t	SNVT_time_sec	<b>EA reg I-time</b>					
<b>ORS Reg.</b>									
356	1382	nviORS_X1	SNVT_temp_p	<b>ORS Brkpnt_X1</b> Breakpoint X1 setting according to the diagram for ORS.	-5.00	NV 359	°C	-20.00	
357	1383	nvoORS_X1	SNVT_temp_p	<b>ORS Brkpnt_X1</b>					
358	1384	nviORS_X2	SNVT_temp_p	<b>ORS Brkpnt_X2</b> Breakpoint X2 setting according to the diagram for ORS.	NV 357	NV 361	°C	-10.00	
359	1385	nvoORS_X2	SNVT_temp_p	<b>ORS Brkpnt_X2</b>					
360	1386	nviORS_X3	SNVT_temp_p	<b>ORS Brkpnt_X3</b> Breakpoint X3 setting according to the diagram for ORS.	NV 359	NV 363	°C	10.00	
361	1387	nvoORS_X3	SNVT_temp_p	<b>ORS Brkpnt_X3</b>					
362	1388	nviORS_X4	SNVT_temp_p	<b>ORS Brkpnt_X4</b> Breakpoint X4 setting according to the diagram for ORS.	NV 361	50.00	°C	20.00	
363	1389	nvoORS_X4	SNVT_temp_p	<b>ORS Brkpnt_X4</b>					
364	1390	nviORS_Y1	SNVT_temp_p	<b>ORS Brkpnt_Y1</b> Breakpoint Y1 setting according to the diagram for ORS.	10.00	40.00	°C	21.50	
365	1391	nvoORS_Y1	SNVT_temp_p	<b>ORS Brkpnt_Y1</b>					
366	1392	nviORS_Y2	SNVT_temp_p	<b>ORS Brkpnt_Y2</b> Breakpoint Y2 setting according to the diagram for ORS.	10.00	40.00	°C	21.50	
367	1393	nvoORS_Y2	SNVT_temp_p	<b>ORS Brkpnt_Y2</b>					
368	1394	nviORS_Y3	SNVT_temp_p	<b>ORS Brkpnt_Y3</b> Breakpoint Y3 setting according to the diagram for ORS.	10.00	40.00	°C	21.50	
369	1395	nvoORS_Y3	SNVT_temp_p	<b>ORS Brkpnt_Y3</b>					
370	1396	nviORS_Y4	SNVT_temp_p	<b>ORS Brkpnt_Y4</b> Breakpoint Y4 setting according to the diagram for ORS.	10.00	40.00	°C	21.50	
371	1397	nvoORS_Y4	SNVT_temp_p	<b>ORS Brkpnt_Y4</b>					
<b>ORE Reg.</b>									
372	1402	nviORE_X1	SNVT_temp_p	<b>ORE Brkpnt_X1</b> Breakpoint X1 setting according to the diagram for ORE.	-5.00	NV 375	°C	-20.00	
373	1403	nvoORE_X1	SNVT_temp_p	<b>ORE Brkpnt_X1</b>					
374	1404	nviORE_X2	SNVT_temp_p	<b>ORE Brkpnt_X2</b> Breakpoint X2 setting according to the diagram for ORE.	NV 373	NV 377	°C	-10.00	
375	1405	nvoORE_X2	SNVT_temp_p	<b>ORE Brkpnt_X2</b>					
376	1406	nviORE_X3	SNVT_temp_p	<b>ORE Brkpnt_X3</b> Breakpoint X3 setting according to the diagram for ORE.	NV 375	NV 379	°C	10.00	
377	1407	nvoORE_X3	SNVT_temp_p	<b>ORE Brkpnt_X3</b>					

NV Index	SNVT No	SNVT Name	SNVT Type	Description	Min	Max	Unit	Default	Misc
378	1408	nviORE_X4	SNVT_temp_p	<b>ORE Brkpnt_X4</b> Breakpoint X4 setting according to the diagram for ORE.	NV 377	50.00	°C	20.00	
379	1409	nvoORE_X4	SNVT_temp_p	<b>ORE Brkpnt_X4</b>					
380	1410	nviORE_Y1	SNVT_temp_p	<b>ORE Brkpnt_X4</b> Breakpoint Y1 setting according to the diagram for ORE.	10.00	40.00	°C	21.50	
381	1411	nvoORE_Y1	SNVT_temp_p	<b>ORE Brkpnt_Y1</b>					
382	1412	nviORE_Y2	SNVT_temp_p	<b>ORE Brkpnt_Y2</b> Breakpoint Y2 setting according to the diagram for ORE.	10.00	40.00	°C	21.50	
383	1413	nvoORE_Y2	SNVT_temp_p	<b>ORE Brkpnt_Y2</b>					
384	1414	nviORE_Y3	SNVT_temp_p	<b>ORE Brkpnt_Y3</b> Breakpoint Y3 setting according to the diagram for ORE.	10.00	40.00	°C	21.50	
385	1415	nvoORE_Y3	SNVT_temp_p	<b>ORE Brkpnt_Y3</b>					
386	1416	nviORE_Y4	SNVT_temp_p	<b>ORE Brkpnt_Y4</b> Breakpoint Y4 setting according to the diagram for ORE.	10.00	40.00	°C	21.50	
387	1417	nvoORE_Y4	SNVT_temp_p	<b>ORE Brkpnt_Y4</b>					
<b>AHU external sensors</b>									
388	1430	nviRoomTempExtFu	SNVT_count	<b>EA/Room temp ext func</b> 0=Average, 1=Min, 2=Max	0	2		0	
389	1431	nvoRoomTempExtFu	SNVT_count	<b>EA/Room temp ext func</b>					
390	1432	nviRoomTempBMSFu	SNVT_count	<b>EA/Room temp from BMS func</b>	0	1		0	
391	1433	nvoRoomTempBMSFu	SNVT_count	<b>EA/Room temp from BMS func</b>					
392	1434	nviRoomTempBMS	SNVT_temp_p	<b>EA/Room temp from BMS</b>	-55.00	125.00	°C	0.00	
393	1435	nvoRoomTempBMS	SNVT_temp_p	<b>EA/Room temp from BMS</b>					
394	1436	nviRoomTempBMSA1	SNVT_time_min	<b>EA/Room temp from BMS alarm</b>	0	9999	min	5	
395	1437	nvoRoomTempBMSA1	SNVT_time_min	<b>EA/Room temp from BMS alarm</b>					
396	1450	nviOutdTempExtFu	SNVT_count	<b>Outdoor temp ext func</b> 0=Average, 1=Min, 2=Max	0	2		0	
397	1451	nvoOutdTempExtFu	SNVT_count	<b>Outdoor temp ext func</b>					
398	1452	nviOutdTempBMSFu	SNVT_count	<b>Outdoor temp from BMS func</b>	0	1		0	
399	1453	nvoOutdTempBMSFu	SNVT_count	<b>Outdoor temp from BMS func</b>					
400	1454	nviOutdTempBMS	SNVT_temp_p	<b>Outdoor temp from BMS</b>	-55.00	125.00	°C	0.00	
401	1455	nvoOutdTempBMS	SNVT_temp_p	<b>Outdoor temp from BMS</b>					
402	1456	nviOutdTempBMSA1	SNVT_time_min	<b>Outdoor temp from BMS alarm</b>	0	9999	min	5	
403	1457	nvoOutdTempBMSA1	SNVT_time_min	<b>Outdoor temp from BMS alarm</b>					

NV Index	SNVT No	SNVT Name	SNVT Type	Description	Min	Max	Unit	Default	Misc
AHU Heat exchange									
404	1462	nviRHX_defr_func	SNVT_switch	<b>Defrost Heat X Act</b> Setting for activating the defrost function for the rotary heat exchanger.	0	1		0	
405	1463	nvoRHX_defr_func	SNVT_switch	<b>Defrost Heat X</b>					
406	1464	nviRHX_defr_cal	SNVT_switch	<b>Defrost Heat X Cal</b>	0	1		0	
407	1465	nvoRHX_defr_cal	SNVT_switch	<b>Defrost Heat X Cal</b>					
408	1466	nviRHX_defr_sta	SNVT_press_p	<b>Defrost Heat X start</b>	30.0	100.0	Pa	50.0	
409	1467	nvoRHX_defr_sta	SNVT_press_p	<b>Defrost Heat X start</b>					
410	1472	nviRHX_COc_func	SNVT_switch	<b>Carry over cont Heat X Act</b> Setting for activating the carry over control function for the rotary heat exchanger.	0	1		0	
411	1473	nvoRHX_COc_func	SNVT_switch	<b>Carry over cont Heat X</b>					
412	1478	nviRHX_MinEAtmpF	SNVT_switch	<b>Min EA temp Heat X Act</b>	0	1		0	
413	1479	nvoRHX_MinEAtmpF	SNVT_switch	<b>Min EA temp Heat X</b>					
414	1480	nviRHX_MinEAtmpS	SNVT_temp_p	<b>Min EA temp Heat X stpnt</b>	-40.00	20.00	°C	5.00	
415	1481	nvoRHX_MinEAtmpS	SNVT_temp_p	<b>Min EA temp Heat X stpnt</b>					
416	1482	nviRHX_MinEAtmpP	SNVT_temp_p	<b>Min EA temp Heat X P-band</b>	1.00	40.00	K	8.00	
417	1483	nvoRHX_MinEAtmpP	SNVT_temp_p	<b>Min EA temp Heat X P-band</b>					
418	1484	nviRHX_MinEAtmpI	SNVT_time_sec	<b>Min EA temp Heat X I-time</b>	0	30000	s	30	
419	1485	nvoRHX_MinEAtmpI	SNVT_time_sec	<b>Min EA temp Heat X I-time</b>					
420	1524	nviPCHX_defr_lim	SNVT_temp_p	<b>P/C.HX.defrost limit</b> PHX is default 3°C, CHX is default 5°C.	-10.00	5.00	°C		
421	1525	nvoPCHX_defr_lim	SNVT_temp_p	<b>P/C.HX.defrost limit</b>					
422	1526	nviPCHX_defr_P-b	SNVT_temp_p	<b>P/C.HX.defrost P-band</b>	1.00	40.00	K	20.00	
423	1527	nvoPCHX_defr_P-b	SNVT_temp_p	<b>P/C.HX.defrost P-band</b>					
424	1528	nviPCHX_defr_I-t	SNVT_time_sec	<b>P/C.HX.defrost I-time</b>	1	600	s	60	
425	1529	nvoPCHX_defr_I-t	SNVT_time_sec	<b>P/C.HX.defrost I-time</b>					
426	1538	nviHX_tmp_reg_Pb	SNVT_temp_p	<b>P/C.HX.defrost P-band</b>	1.00	10.00	K	6.00	
427	1539	nvoHX_tmp_reg_Pb	SNVT_temp_p	<b>P/C.HX.defrost P-band</b>					
428	1540	nviHX_tmp_reg_It	SNVT_time_sec	<b>P/C.HX.defrost I-time</b>	1	1800	s	50	
429	1541	nvoHX_tmp_reg_It	SNVT_time_sec	<b>P/C.HX.defrost I-time</b>					

NV Index	SNVT No	SNVT Name	SNVT Type	Description	Min	Max	Unit	Default	Misc
AHU Heat/Cool									
430	1550	nviReHeat_P-band	SNVT_temp_p	ReHeat P-band	1.00	10.00	K	8.00	
431	1551	nvoReHeat_P-band	SNVT_temp_p	ReHeat P-band					
432	1552	nviReHeat_I-time	SNVT_time_sec	ReHeat I-time	1	1800	s	70	
433	1553	nvoReHeat_I-time	SNVT_time_sec	ReHeat I-time					
434	1572	nviEXreg_func	SNVT_count	Extra reg seq func 0=Inactive, 1=Heat, 2=Cool, 3=Heat and Cool.	0	3		0	
435	1573	nvoEXreg_func	SNVT_count	Extra reg seq func					
436	1574	nviEXreg_OP_func	SNVT_count	Extra reg seq output func 0=0-10V, 1=10-0V	0	1		0	
437	1575	nvoEXreg_OP_func	SNVT_count	Extra reg seq output func					
438	1576	nviEXreg_H_MaxOP	SNVT_lev_percent	Extra reg seq heat max output Maximum output signal setting for the extra regulation sequence.	0.00	100.00	%	100.00	
439	1577	nvoEXreg_H_MaxOP	SNVT_lev_percent	Extra reg seq heat max output					
440	1578	nviEXreg_C_MaxOP	SNVT_lev_percent	Extra reg seq cool max output Maximum output signal setting for the extra regulation sequence.	0.00	100.00	%	100.00	
441	1579	nvoEXreg_C_MaxOP	SNVT_lev_percent	Extra reg seq cool max output					
442	1580	nviEXreg_H_P-b	SNVT_temp_p	Extra reg seq heat P-band	1.00	10.00	K	8	
443	1581	nvoEXreg_H_P-b	SNVT_temp_p	Extra reg seq heat P-band					
444	1582	nviEXreg_H_I-t	SNVT_time_sec	Extra reg seq heat I-time	1	1800	s	70	
445	1583	nvoEXreg_H_I-t	SNVT_time_sec	Extra reg seq heat I-time					
446	1584	nviEXreg_C_P-b	SNVT_temp_p	Extra reg seq cool P-band	1.00	10.00	K	6	
447	1585	nvoEXreg_C_P-b	SNVT_temp_p	Extra reg seq cool P-band					
448	1586	nviEXreg_C_I-t	SNVT_time_sec	Extra reg seq cool I-time	1	1800	s	60	
449	1587	nvoEXreg_C_I-t	SNVT_time_sec	Extra reg seq cool I-time					
450	1600	nviEXreg_Pro_Fu	SNVT_switch	Extra reg temp protection func	0	1		0	1.10
451	1601	nvoEXreg_Pro_Fu	SNVT_switch	Extra reg temp protection func					
452	1602	nviEXreg_Pro_Tmp	SNVT_temp_p	Extra reg temp protection temp	-50.00	100.00	°C	0.00	1.10
453	1603	nvoEXreg_Pro_Tmp	SNVT_temp_p	Extra reg temp protection temp					
454	1604	nviEXreg_Pro_Al	SNVT_time_min	Extra reg temp protection alarm	0	9999	min	5	1.10
455	1605	nvoEXreg_Pro_Al	SNVT_time_min	Extra reg temp protection alarm					
456	1620	nviCool_reg_func	SNVT_count	Cool on/off regulation func 0=Inactive, 1=1 step, 2=2 steps, 3=3 steps.	0	3		0	
457	1621	nvoCool_reg_func	SNVT_count	Cool on/off regulation func					
458	1622	nviCool_SA_NZ	SNVT_temp_p	Cool SA neutral zone	0.50	10.00	K	2.00	
459	1623	nvoCool_SA_NZ	SNVT_temp_p	Cool SA neutral zone					
460	1624	nviCool_EA_NZ	SNVT_temp_p	Cool EA neutral zone	0.50	10.00	K	2.00	
461	1625	nvoCool_EA_NZ	SNVT_temp_p	Cool EA neutral zone					
462	1626	nviCoolLimit1	SNVT_temp_p	Cool Outd temp limit 1	0.00	30.00	°C	15.00	
463	1627	nvoCoolLimit1	SNVT_temp_p	Cool Outd temp limit 1					
464	1628	nviCoolLimit2	SNVT_temp_p	Cool Outd temp limit 2	0.00	30.00	°C	18.00	
465	1629	nvoCoolLimit2	SNVT_temp_p	Cool Outd temp limit 2					
466	1630	nviCoolLimit3	SNVT_temp_p	Cool Outd temp limit 3	0.00	30.00	°C	20.00	
467	1631	nvoCoolLimit3	SNVT_temp_p	Cool Outd temp limit 3					
468	1632	nviSFcoolMinflow	SNVT_flow	SA Cool min air flow	0	NV 89	l/s		
469	1633	nvoSFcoolMinflow	SNVT_flow	SA Cool min air flow					
470	1634	nviEFcoolMinflow	SNVT_flow	EA Cool min air flow	0	NV 90	l/s		
471	1635	nvoEFcoolMinflow	SNVT_flow	EA Cool min air flow					

NV Index	SNVT No	SNVT Name	SNVT Type	Description	Min	Max	Unit	Default	Misc
472	1636	nviCool_restart	SNVT_time_min	<b>Cool restart time</b> Setting of cool restart time between start-start.	0	15	min	5	
473	1637	nvoCool_restart	SNVT_time_min	<b>Cool restart time</b>					
474	1638	nviCoolstep_time	SNVT_time_min	<b>Cool step time</b> Setting of on/off cooling and COOL DX time delay between steps.	0	10	min	5	
475	1639	nvoCoolstep_time	SNVT_time_min	<b>Cool step time</b>					
476	1640	nviCoolStillTime	SNVT_time_min	<b>Cool stand still time</b> Setting of on/off cooling and COOL DX time delay before stop-start	0	20	min	5	
477	1641	nvoCoolStillTime	SNVT_time_min	<b>Cool stand still time</b>					
478	1642	nviCool_P-band	SNVT_temp_p	<b>Cool P-band</b>	1.00	10.00	K	6	
479	1643	nvoCool_P-band	SNVT_temp_p	<b>Cool P-band</b>					
480	1644	nviCool_I-time	SNVT_time_sec	<b>Cool I-time</b>	1	1800	s	60	
481	1645	nvoCool_I-time	SNVT_time_sec	<b>Cool I-time</b>					
Summer night cool/Intermittent night heat /Morning boost									
482	1666	nviNC_func	SNVT_switch	<b>Smr Nght Cool Act</b>	0	1		0	
483	1667	nvoNC_func	SNVT_switch	<b>Smr Nght Cool</b>					
484	1668	nviNC_start_h	SNVT_time_hour	<b>Smr nght cool strt hour</b>	0	23	h	23	
485	1669	nvoNC_start_h	SNVT_time_hour	<b>Smr nght cool strt hour</b>					
486	1670	nviNC_start_m	SNVT_time_min	<b>Smr nght cool strt min</b>	0	59	min	0	
487	1671	nvoNC_start_m	SNVT_time_min	<b>Smr nght cool strt min</b>					
488	1672	nviNC_stop_h	SNVT_time_hour	<b>Smr nght cool stop hour</b>	0	23	h	23	
489	1673	nvoNC_stop_h	SNVT_time_hour	<b>Smr nght cool stop hour</b>					
490	1674	nviNC_stop_m	SNVT_time_min	<b>Smr nght cool stop min</b>	0	59	min	0	
491	1675	nvoNC_stop_m	SNVT_time_min	<b>Smr nght cool stop min</b>					
492	1676	nviNC_OUTlimit	SNVT_temp_p	<b>Smr nght cl outd temp lmt</b>	-5.00	15.00	°C	10.00	
493	1677	nvoNC_OUTlimit	SNVT_temp_p	<b>Smr nght cl outd temp lmt</b>					
494	1678	nviNC_starttemp	SNVT_temp_p	<b>Smr Nght cl room strt temp</b>	17.00	27.00	°C	22.00	
495	1679	nvoNC_starttemp	SNVT_temp_p	<b>Smr Nght cl room strt temp</b>					
496	1680	nviNC_stoptemp	SNVT_temp_p	<b>Smr Nght cl room stop temp</b>	12.00	22.00	°C	16.00	
497	1681	nvoNC_stoptemp	SNVT_temp_p	<b>Smr Nght cl room stop temp</b>					
498	1682	nviNC_SAtempset	SNVT_temp_p	<b>Smr nght cl SA temp</b>	0.00	20.00	°C	10.00	
499	1683	nvoNC_SAtempset	SNVT_temp_p	<b>Smr nght cl SA temp</b>					
500	1690	nviNH_func	SNVT_switch	<b>Intrm Nght Heat Act</b>	0	1		0	
501	1691	nvoNH_func	SNVT_switch	<b>Intrm Nght Heat</b>					
502	1692	nviNH_SAflowset	SNVT_flow	<b>Int Nght ht SA airflow</b>	NV 87	NV 89	l/s		
503	1693	nvoNH_SAflowset	SNVT_flow	<b>Int Nght ht SA airflow</b>					
504	1694	nviNH_SApres	SNVT_press_p	<b>Int.Night heat SA press set</b>	20	750	Pa	100	
505	1695	nvoNH_SApres	SNVT_press_p	<b>Int.Night heat SA press set</b>					
506	1696	nviNH_starttemp	SNVT_temp_p	<b>Int Nght ht room strt temp</b>	5.00	NV 509	°C	16.00	
507	1697	nvoNH_starttemp	SNVT_temp_p	<b>Int Nght ht room strt temp</b>					
508	1698	nviNH_stoptemp	SNVT_temp_p	<b>Int Nght ht room stop temp</b>	NV 507	25.00	°C	18.00	
509	1699	nvoNH_stoptemp	SNVT_temp_p	<b>Int Nght ht room stop temp</b>					
510	1700	nviNH_SAtempset	SNVT_temp_p	<b>Int Nght ht SA temp</b>	5.00	50.00	°C	28.00	
511	1701	nvoNH_SAtempset	SNVT_temp_p	<b>Int Nght ht SA temp</b>					
512	1708	nviMB_func	SNVT_switch	<b>Mrn bst Act</b>	0	1		0	
513	1709	nvoMB_func	SNVT_switch	<b>Mrn bst</b>					
514	1710	nviMornboost_h	SNVT_time_hour	<b>Mrn bst hour</b>	0	23	h	0	
515	1711	nvoMornboost_h	SNVT_time_hour	<b>Mrn bst hour</b>					
516	1712	nviMornboost_m	SNVT_time_min	<b>Mrn bst min</b>	0	59	min	0	
517	1713	nvoMornboost_m	SNVT_time_min	<b>Mrn bst min</b>					
518	1714	nviMB_SAflowset	SNVT_flow	<b>Mrn bst SA airflow</b>	NV 87	NV 89	l/s		

NV Index	SNVT No	SNVT Name	SNVT Type	Description	Min	Max	Unit	Default	Misc
519	1715	nvoMB_SAflowset	SNVT_flow	Mrn bst SA airflow					
520	1716	nviMB_SApres	SNVT_press_p	Mrn bst SA press set	20	750	Pa	100	
521	1717	nvoMB_SApres	SNVT_press_p	Mrn bst SA press set					
Cooling boost/heating boost									
522	1724	nviC_boostMode	SNVT_count	Cooling bst reg mode 0=Inactive, 1=Comfort, 2=Economy, 3=Sequence, 4=Comfort and Economy, 5=Economy and Sequence	0	5		0	
523	1725	nvoC_boostMode	SNVT_count	Cooling bst reg mode					
524	1726	nviC_boostStart	SNVT_temp_p	Cooling bst com start limit	2.00	10.00	K	3.00	
525	1727	nvoC_boostStart	SNVT_temp_p	Cooling bst com start limit					
526	1728	nviC_boostSpeed	SNVT_lev_percent	Cooling bst com reg speed	1	25	%/s	4	
527	1729	nvoC_boostSpeed	SNVT_lev_percent	Cooling bst com reg speed					
528	1730	nviC_boostP-band	SNVT_temp_p	Cooling bst P-band	1	10.00	K		
529	1731	nvoC_boostP-band	SNVT_temp_p	Cooling bst P-band					
530	1732	nviC_boostI-time	SNVT_time_sec	Cooling bst I-time	1	1800	s		
531	1733	nvoC_boostI-time	SNVT_time_sec	Cooling bst I-time					
532	1738	nviH_boostmode	SNVT_count	Heating bst reg mode	0	1		0	
533	1739	nvoH_boostmode	SNVT_count	Heating bst reg mode					
534	1740	nviH_boostStart	SNVT_temp_p	Heating bst com start limit	2.00	10.00	K	3.00	
535	1741	nvoH_boostStart	SNVT_temp_p	Heating bst com start limit					
536	1742	nviH_boostSpeed	SNVT_lev_percent	Heating bst com reg speed	1	25	%/s	4	
537	1743	nvoH_boostSpeed	SNVT_lev_percent	Heating bst com reg speed					
Xzone function									
538	1748	nviXZ_ReheatFunc	SNVT_count	Xzone reheat func	0	1		0	
539	1749	nvoXZ_ReheatFunc	SNVT_count	Xzone reheat func					
540	1752	nviXZ_CoolFunc	SNVT_count	Xzone cool func	0	1		0	
541	1753	nvoXZ_CoolFunc	SNVT_count	Xzone cool func					
Xzone temperature regulation									
542	1756	nviXZ_Tempregmod	SNVT_count	Xzone tempregmode 1=ERS-1, 2=ERS-2, 3=SA, 4=EA, 5=ORS, 6=ORE	1	6		1	
543	1757	nvoXZ_Tempregmod	SNVT_count	Xzone tempregmode					
Xzone ERS-1 reg.									
544	1760	nviXZ_ERS1step	SNVT_count	Xzone ERS 1 Step Curve setting according to the diagram for ERS 1.	1	4			
545	1761	nvoXZ_ERS1step	SNVT_count	Xzone ERS 1 Step					
546	1762	nviXZ_ERS1diff	SNVT_temp_p	Xzone SA temp diff set ERS 1 Supply air temp differential setting according to the diagram for ERS 1.	1	7.00	K	2.00	
547	1763	nvoXZ_ERS1diff	SNVT_temp_p	Xzone SA temp diff set ERS 1					
548	1764	nviXZ_ERS1brkpnt	SNVT_temp_p	Xzone ERS 1 Brkpnt Breakpoint temp setting according to the diagram for ERS 1.	12.00	26.00	°C	22.00	
549	1765	nvoXZ_ERS1brkpnt	SNVT_temp_p	Xzone ERS 1 Brkpnt					
Xzone ERS-2 reg.									
550	1770	nviXZ_ERS2_X1	SNVT_temp_p	Xzone ERS 2 Brkpnt_X1 Breakpoint X1 setting according to the diagram for ERS 2.	10	NV 553	°C	15.00	
551	1771	nvoXZ_ERS2_X1	SNVT_temp_p	Xzone ERS 2 Brkpnt_X1					
552	1772	nviXZ_ERS2_X2	SNVT_temp_p	Xzone ERS 2 Brkpnt_X2 Breakpoint X2 setting according to the diagram for ERS 2.	NV 551	NV 555	°C	20.00	
553	1773	nvoXZ_ERS2_X2	SNVT_temp_p	Xzone ERS 2 Brkpnt_X2					
554	1774	nviXZ_ERS2_X3	SNVT_temp_p	Xzone ERS 2 Brkpnt_X3 Breakpoint X3 setting according to the diagram for ERS 2.	NV 553	NV 557	°C	22.00	
555	1775	nvoXZ_ERS2_X3	SNVT_temp_p	Xzone ERS 2 Brkpnt_X3					

NV Index	SNVT No	SNVT Name	SNVT Type	Description	Min	Max	Unit	Default	Misc
556	1776	nviXZ_ERS2_X4	SNVT_temp_p	Xzone ERS 2 Brkpnt_X4 Breakpoint X4 setting according to the diagram for ERS 2.	NV 555	40.00	°C	24.00	
557	1777	nvoXZ_ERS2_X4	SNVT_temp_p	Xzone ERS 2 Brkpnt_X4					
558	1778	nviXZ_ERS2_Y1	SNVT_temp_p	Xzone ERS 2 Brkpnt_Y1 Breakpoint Y1 setting according to the diagram for ERS 2.	10.00	40.00	°C	20.00	
559	1779	nvoXZ_ERS2_Y1	SNVT_temp_p	Xzone ERS 2 Brkpnt_Y1					
560	1780	nviXZ_ERS2_Y2	SNVT_temp_p	Xzone ERS 2 Brkpnt_Y2 Breakpoint Y2 setting according to the diagram for ERS 2.	10.00	40.00	°C	18.00	
561	1781	nvoXZ_ERS2_Y2	SNVT_temp_p	Xzone ERS 2 Brkpnt_Y2					
562	1782	nviXZ_ERS2_Y3	SNVT_temp_p	Xzone ERS 2 Brkpnt_Y3 Breakpoint Y3 setting according to the diagram for ERS 2.	10.00	40.00	°C	14.00	
563	1783	nvoXZ_ERS2_Y3	SNVT_temp_p	Xzone ERS 2 Brkpnt_Y3					
564	1784	nviXZ_ERS2_Y4	SNVT_temp_p	Xzone ERS 2 Brkpnt_Y4 Breakpoint Y4 setting according to the diagram for ERS 2.	10.00	40.00	°C	12.00	
565	1785	nvoXZ_ERS2_Y4	SNVT_temp_p	Xzone ERS 2 Brkpnt_Y4					
<b>Xzone SA Reg.</b>									
566	1790	nviXZ_SAtempset	SNVT_temp_p	Xzone SA temp Supply air temperature setting, for supply air temp regulation mode.	10.00	40.00	°C	21.00	
567	1791	nvoXZ_SAtempset	SNVT_temp_p	Xzone SA temp					
<b>Xzone EA Reg.</b>									
568	1796	nviXZ_EAtempset	SNVT_temp_p	Xzone EA temp Extract air/room temperature setting, for Extract air/room temp regulation mode.	10.00	40.00	°C	21.00	
569	1797	nvoXZ_EAtempset	SNVT_temp_p	Xzone EA temp					
570	1798	nviXZ_MinSAtemp	SNVT_temp_p	Xzone SA Min temp Supply air min. set point during EA/room regulation mode.	8.00	20.00	°C	16.00	
571	1799	nvoXZ_MinSAtemp	SNVT_temp_p	Xzone SA Min temp					
572	1800	nviXZ_MaxSAtemp	SNVT_temp_p	Xzone SA Max temp Supply air max. set point during EA/room regulation mode.	16.00	50.00	°C	28.00	
573	1801	nvoXZ_MaxSAtemp	SNVT_temp_p	Xzone SA Max temp					
574	1802	nviXZ_EA_P-band	SNVT_temp_p	Xzone P-band	1.00	10.00	K	5.00	
575	1803	nvoXZ_EA_P-band	SNVT_temp_p	Xzone P-band					
576	1804	nviXZ_EA_I-time	SNVT_time_sec	Xzone I-time	1	1800	s	180	
577	1805	nvoXZ_EA_I-time	SNVT_time_sec	Xzone I-time					
<b>Xzone ORS Reg.</b>									
578	1806	nviXZ_ORS_X1	SNVT_temp_p	Xzone ORS Brkpnt_X1 Breakpoint X1 setting according to the diagram for ORS.	-5.00	NV 581	°C	-20.00	
579	1807	nvoXZ_ORS_X1	SNVT_temp_p	Xzone ORS Brkpnt_X1					
580	1808	nviXZ_ORS_X2	SNVT_temp_p	Xzone ORS Brkpnt_X2 Breakpoint X2 setting according to the diagram for ORS.	NV 579	NV 583	°C	-10.00	
581	1809	nvoXZ_ORS_X2	SNVT_temp_p	Xzone ORS Brkpnt_X2					
582	1810	nviXZ_ORS_X3	SNVT_temp_p	Xzone ORS Brkpnt_X3 Breakpoint X3 setting according to the diagram for ORS.	NV 581	NV 585	°C	10.00	
583	1811	nvoXZ_ORS_X3	SNVT_temp_p	Xzone ORS Brkpnt_X3					
584	1812	nviXZ_ORS_X4	SNVT_temp_p	Xzone ORS Brkpnt_X4 Breakpoint X4 setting according to the diagram for ORS.	NV 583	50.00	°C	20.00	
585	1813	nvoXZ_ORS_X4	SNVT_temp_p	Xzone ORS Brkpnt_X4					
586	1814	nviXZ_ORS_Y1	SNVT_temp_p	Xzone ORS Brkpnt_Y1 Breakpoint Y1 setting according to the diagram for ORS.	10.00	40.00	°C	21.50	
587	1815	nvoXZ_ORS_Y1	SNVT_temp_p	Xzone ORS Brkpnt_Y1					

NV Index	SNVT No	SNVT Name	SNVT Type	Description	Min	Max	Unit	Default	Misc
588	1816	nviXZ_ORS_Y2	SNVT_temp_p	Xzone ORS Brkpnt_Y2 Breakpoint Y2 setting according to the diagram for ORS.	10.00	40.00	°C	21.50	
589	1817	nvoXZ_ORS_Y2	SNVT_temp_p	Xzone ORS Brkpnt_Y2					
590	1818	nviXZ_ORS_Y3	SNVT_temp_p	Xzone ORS Brkpnt_Y3 Breakpoint Y3 setting according to the diagram for ORS.	10.00	40.00	°C	21.50	
591	1819	nvoXZ_ORS_Y3	SNVT_temp_p	Xzone ORS Brkpnt_Y3					
592	1820	nviXZ_ORS_Y4	SNVT_temp_p	Xzone ORS Brkpnt_Y4 Breakpoint Y4 setting according to the diagram for ORS.	10.00	40.00	°C	21.50	
593	1821	nvoXZ_ORS_Y4	SNVT_temp_p	Xzone ORS Brkpnt_Y4					
<b>Xzone ORE Reg.</b>									
594	1826	nviXZ_ORE_X1	SNVT_temp_p	Xzone ORE Brkpnt_X1 Breakpoint X1 setting according to the diagram for ORE.	-5.00	NV 597	°C	-20.00	
595	1827	nvoXZ_ORE_X1	SNVT_temp_p	Xzone ORE Brkpnt_X1					
596	1828	nviXZ_ORE_X2	SNVT_temp_p	Xzone ORE Brkpnt_X2 Breakpoint X2 setting according to the diagram for ORE.	NV 595	NV 599	°C	-10.00	
597	1829	nvoXZ_ORE_X2	SNVT_temp_p	Xzone ORE Brkpnt_X2					
598	1830	nviXZ_ORE_X3	SNVT_temp_p	Xzone ORE Brkpnt_X3 Breakpoint X3 setting according to the diagram for ORE.	NV 597	NV 601	°C	10.00	
599	1831	nvoXZ_ORE_X3	SNVT_temp_p	Xzone ORE Brkpnt_X3					
600	1832	nviXZ_ORE_X4	SNVT_temp_p	Xzone ORE Brkpnt_X4 Breakpoint X4 setting according to the diagram for ORE.	NV 599	50.00	°C	20.00	
601	1833	nvoXZ_ORE_X4	SNVT_temp_p	Xzone ORE Brkpnt_X4					
602	1834	nviXZ_ORE_Y1	SNVT_temp_p	Xzone ORE Brkpnt_Y1 Breakpoint Y1 setting according to the diagram for ORE.	10.00	40.00	°C	21.50	
603	1835	nvoXZ_ORE_Y1	SNVT_temp_p	Xzone ORE Brkpnt_Y1					
604	1836	nviXZ_ORE_Y2	SNVT_temp_p	Xzone ORE Brkpnt_Y2 Breakpoint Y2 setting according to the diagram for ORE.	10.00	40.00	°C	21.50	
605	1837	nvoXZ_ORE_Y2	SNVT_temp_p	Xzone ORE Brkpnt_Y2					
606	1838	nviXZ_ORE_Y3	SNVT_temp_p	Xzone ORE Brkpnt_Y3 Breakpoint Y3 setting according to the diagram for ORE.	10.00	40.00	°C	21.50	
607	1839	nvoXZ_ORE_Y3	SNVT_temp_p	Xzone ORE Brkpnt_Y3					
608	1840	nviXZ_ORE_Y4	SNVT_temp_p	Xzone ORE Brkpnt_Y4 Breakpoint Y4 setting according to the diagram for ORE.	10.00	40.00	°C	21.50	
609	1841	nvoXZ_ORE_Y4	SNVT_temp_p	Xzone ORE Brkpnt_Y4					
<b>Xzone external sensors</b>									
610	1854	nviXZ_RoomTempFu	SNVT_count	Xzone EA/Room temp ext func 0=Average, 1=Min, 2=Max	0	2		0	
611	1855	nvoXZ_RoomTempFu	SNVT_count	Xzone EA/Room temp ext func					
612	1856	nviXZ_RoomBMSFu	SNVT_count	Xzone EA/Room temp from BMS func	0	1		0	
613	1857	nvoXZ_RoomBMSFu	SNVT_count	Xzone EA/Room temp from BMS func					
614	1858	nviXZ_RoomTmpBMS	SNVT_temp_p	Xzone EA/Room temp from BMS	-55.00	125.00	°C	0.00	
615	1859	nvoXZ_RoomTmpBMS	SNVT_temp_p	Xzone EA/Room temp from BMS					
616	1860	nviXZ_RoomBMSA1	SNVT_time_min	Xzone EA/Room temp from BMS alarm	0	9999	min	5	
617	1861	nvoXZ_RoomBMSA1	SNVT_time_min	Xzone EA/Room temp from BMS alarm					
<b>Xzone Heat/Cool</b>									
618	1866	nviXZ_ReHeat_P-b	SNVT_temp_p	Xzone ReHeat P-band	1.00	10.00	K	8.00	
619	1867	nvoXZ_ReHeat_P-b	SNVT_temp_p	Xzone ReHeat P-band					
620	1868	nviXZ_ReHeat_I-t	SNVT_time_sec	Xzone ReHeat I-time	1	1800	s	70	
621	1869	nvoXZ_ReHeat_I-t	SNVT_time_sec	Xzone ReHeat I-time					
622	1888	nviXZ_Cool_reg_f	SNVT_count	Xzone Cool on/off regulation func 0=Inactive, 1=1 step, 2=2 steps, 3=3 steps.	0	3		0	
623	1889	nvoXZ_Cool_reg_f	SNVT_count	Xzone Cool on/off regulation func					

NV Index	SNVT No	SNVT Name	SNVT Type	Description	Min	Max	Unit	Default	Misc
624	1890	nviXZ_Cool_SA_NZ	SNVT_temp_p	Xzone Cool SA neutral zone	0.50	10.00	K	2.00	
625	1891	nvoXZ_Cool_SA_NZ	SNVT_temp_p	Xzone Cool SA neutral zone					
626	1892	nviXZ_Cool_EA_NZ	SNVT_temp_p	Xzone Cool EA neutral zone	0.50	10.00	K	2.00	
627	1893	nvoXZ_Cool_EA_NZ	SNVT_temp_p	Xzone Cool EA neutral zone					
628	1894	nviXZ_Cool_P-b	SNVT_temp_p	Xzone Cool P-band	1.00	10.00	K	6.00	
629	1895	nvoXZ_Cool_P-b	SNVT_temp_p	Xzone Cool P-band					
630	1896	nviXZ_Cool_I-t	SNVT_time_sec	Xzone Cool I-time	1	1800	s	60	
631	1897	nvoXZ_Cool_I-t	SNVT_time_sec	Xzone Cool I-time					
Pre-heat									
632	1918	nviPreHeatFunc	SNVT_count	Preheating func	0	1		0	
633	1919	nvoPreHeatFunc	SNVT_count	Preheating func					
634	1920	nviPreHeatTmpSet	SNVT_temp_p	Preheating temp set	-40.00	40.00	°C	5.00	
635	1921	nvoPreHeatTmpSet	SNVT_temp_p	Preheating temp set					
636	1922	nviPreHeat_P-b	SNVT_temp_p	Preheat P-band	1.00	10.00	K	8.00	
637	1923	nvoPreHeat_P-b	SNVT_temp_p	Preheat P-band					
638	1924	nviPreHeat_I-t	SNVT_time_sec	Preheat I-time	1	1800	s	70	
639	1925	nvoPreHeat_I-t	SNVT_time_sec	Preheat I-time					
ReCO <sub>2</sub>									
640	1944	nviReCO2_CO2_fu	SNVT_count	ReCO2 CO2 func 0=Inactive, 1=CO <sub>2</sub> , 2=CO <sub>2</sub> and air flow boost	0	2		0	
641	1945	nvoReCO2_CO2_fu	SNVT_count	ReCO2 CO2 func					
642	1946	nviReCO2_Temp_fu	SNVT_count	ReCO2 temp func 0=Inactive, 1=Heat, 2=Cool, 3=Heat and Cool.	0	3		0	
643	1947	nvoReCO2_Temp_fu	SNVT_count	ReCO2 temp func					
644	1950	nviReCO2_CO2_set	SNVT_lev_percent	ReCO2 CO2 set	0.00	100.00	%	50.00	
645	1951	nvoReCO2_CO2_set	SNVT_lev_percent	ReCO2 CO2 set					
646	1952	nviReCO2_MinOutA	SNVT_flow	ReCO2 min outdoor air	0	NV 89	l/s		
647	1953	nvoReCO2_MinOutA	SNVT_flow	ReCO2 min outdoor air					
648	1954	nviReCO2_MinExhA	SNVT_flow	ReCO2 min exhaust air	0	NV 90	l/s		
649	1955	nvoReCO2_MinExhA	SNVT_flow	ReCO2 min exhaust air					
650	1956	nviReCO2_CO2_P-b	SNVT_lev_percent	ReCO2 CO2 P-band	1.00	100.00	%	50.00	
651	1957	nvoReCO2_CO2_P-b	SNVT_lev_percent	ReCO2 CO2 P-band					
652	1958	nviReCO2_CO2_I-t	SNVT_time_sec	ReCO2 CO2 I-time	1	1800	s	60	
653	1959	nvoReCO2_CO2_I-t	SNVT_time_sec	ReCO2 CO2 I-time					
654	1960	nviReCO2_CO2F_Pb	SNVT_lev_percent	ReCO2 CO2 flow P-band	10.00	100.00	%	50.00	
655	1961	nvoReCO2_CO2F_Pb	SNVT_lev_percent	ReCO2 CO2 flow P-band					
656	1962	nviReCO2_CO2F_It	SNVT_time_sec	ReCO2 CO2 flow I-time	1	1800	s	60	
657	1963	nvoReCO2_CO2F_It	SNVT_time_sec	ReCO2 CO2 flow I-time					
658	1964	nviReCO2_Heat_Pb	SNVT_lev_percent	ReCO2 heat P-band	1.00	10.00	K	7.00	
659	1965	nvoReCO2_Heat_Pb	SNVT_lev_percent	ReCO2 heat P-band					
660	1966	nviReCO2_Heat_It	SNVT_time_sec	ReCO2 heat I-time	1	1800	s	70	
661	1967	nvoReCO2_Heat_It	SNVT_time_sec	ReCO2 heat I-time					
662	1968	nviReCO2_Cool_Pb	SNVT_lev_percent	ReCO2 cool P-band	1.00	10.00	K	6.00	
663	1969	nvoReCO2_Cool_Pb	SNVT_lev_percent	ReCO2 cool P-band					
664	1970	nviReCO2_Cool_It	SNVT_time_sec	ReCO2 cool I-time	1	1800	s	60	
665	1971	nvoReCO2_Cool_It	SNVT_time_sec	ReCO2 cool I-time					
Humidity/VOC									
666	1980	nviHumidi_func	SNVT_count	Humidi func 0=Inactive, 1=on/off, 2=0-10V	0	2		0	
667	1981	nvoHumidi_func	SNVT_count	Humidi func					

NV Index	SNVT No	SNVT Name	SNVT Type	Description	Min	Max	Unit	Default	Misc
668	1984	nviHumidi_start	SNVT_lev_percent	Humidi on/off start	10.00	NV 671	%RH	40.00	
669	1985	nvoHumidi_start	SNVT_lev_percent	Humidi on/off start					
670	1986	nviHumidi_stop	SNVT_lev_percent	Humidi on/off stop	NV 669	95.00	%RH	45.00	
671	1988	nvoHumidi_stop	SNVT_lev_percent	Humidi on/off stop					
672	1994	nviHum_0-10_Set	SNVT_lev_percent	Humidi 0-10V set	10.00	95.00	%RH	30.00	
673	1995	nvoHum_0-10_Set	SNVT_lev_percent	Humidi 0-10V set					
674	1996	nviHum_0-10_Max	SNVT_lev_percent	Humidi 0-10V max	10.00	95.00	%RH	80.00	
675	1997	nvoHum_0-10_Max	SNVT_lev_percent	Humidi 0-10V max					
676	1998	nviHum_0-10_SA_P	SNVT_lev_percent	Humidi 0-10V SA P-band	1.00	80.00	%RH	60.00	
677	1999	nvoHum_0-10_SA_P	SNVT_lev_percent	Humidi 0-10V SA P-band					
678	2000	nviHum_0-10_SA_I	SNVT_time_sec	Humidi 0-10V SA I-time	1	1800	s	30	
679	2001	nvoHum_0-10_SA_I	SNVT_time_sec	Humidi 0-10V SA I-time					
680	1998	nviHum_0-10_EA_P	SNVT_lev_percent	Humidi 0-10V EA P-band	1.00	80.00	%RH	60.00	
681	1999	nvoHum_0-10_EA_P	SNVT_lev_percent	Humidi 0-10V EA P-band					
682	2000	nviHum_0-10_EA_I	SNVT_time_sec	Humidi 0-10V EA I-time	1	1800	s	180	
683	2001	nvoHum_0-10_EA_I	SNVT_time_sec	Humidi 0-10V EA I-time					
684	2014	nviDehumidi_Set	SNVT_lev_percent	Dehumidi setpoint	10.00	90.00	%RH	50.00	
685	2015	nvoDehumidi_Set	SNVT_lev_percent	Dehumidi setpoint					
SMART Link									
686	2062	nviSL_WB_HeatSet	SNVT_temp_p	SL WB heat temp set	-40.0	176.0	°C	40.0	
687	2063	nvoSL_WB_HeatSet	SNVT_temp_p	SL WB heat temp set					
688	2064	nviSL_WB_HeatZon	SNVT_temp_p	SL WB heat temp zone	1.0	10.0	K	3.0	
689	2065	nvoSL_WB_HeatZon	SNVT_temp_p	SL WB heat temp zone					
690	2066	nviSL_WB_CoolSet	SNVT_temp_p	SL WB cool temp set	-40.0	176.0	°C	12.0	
691	2067	nvoSL_WB_CoolSet	SNVT_temp_p	SL WB cool temp set					
692	2068	nviSL_WB_CoolZon	SNVT_temp_p	SL WB cool temp zone	1.0	10.0	K	2.0	
693	2069	nvoSL_WB_CoolZon	SNVT_temp_p	SL WB cool temp zone					
694	2080	nviSL_WB_Op_V_Up	SNVT_lev_percent	SL WB op valve upper	5.0	90.0	%	80.0	
695	2081	nvoSL_WB_Op_V_Up	SNVT_lev_percent	SL WB op valve upper					
696	2082	nviSL_WB_Op_V_Lo	SNVT_lev_percent	SL WB op valve lower	70.0	100.0	%	100.0	
697	2083	nvoSL_WB_Op_V_Lo	SNVT_lev_percent	SL WB op valve lower					
698	2084	nviSL_WB_OpDelay	SNVT_time_sec	SL WB op time delay	30	32000	s	60	
699	2085	nvoSL_WB_OpDelay	SNVT_time_sec	SL WB op time delay					
700	2128	nviSL_DX_DeDelay	SNVT_time_sec	SL DX defrost time delay	30	900	s	90	
701	2129	nvoSL_DX_DeDelay	SNVT_time_sec	SL DX defrost time delay					
AYC									
702	2146	nviAYCHeatTmpSet	SNVT_temp_p	AYC heat temp set	10.00	80.00	°C	30.00	
703	2147	nvoAYCHeatTmpSet	SNVT_temp_p	AYC heat temp set					
704	2172	nviAYCHeatOutCX1	SNVT_temp_p	AYC heat out cmp X1	-40.00	NV 707	°C	-20.00	
705	2173	nvoAYCHeatOutCX1	SNVT_temp_p	AYC heat out cmp X1					
706	2174	nviAYCHeatOutCX2	SNVT_temp_p	AYC heat out cmp X2	NV 705	NV 709	°C	0.00	
707	2175	nvoAYCHeatOutCX2	SNVT_temp_p	AYC heat out cmp X2					
708	2176	nviAYCHeatOutCX3	SNVT_temp_p	AYC heat out cmp X3	NV 707	NV 711	°C	5.00	
709	2177	nvoAYCHeatOutCX3	SNVT_temp_p	AYC heat out cmp X3					
710	2178	nviAYCHeatOutCX4	SNVT_temp_p	AYC heat out cmp X4	NV 709	40.00	°C	15.00	
711	2179	nvoAYCHeatOutCX4	SNVT_temp_p	AYC heat out cmp X4					
712	2180	nviAYCHeatOutCY1	SNVT_temp_p	AYC heat out cmp Y1	-40.00	40.00	°C	40.00	
713	2181	nvoAYCHeatOutCY1	SNVT_temp_p	AYC heat out cmp Y1					
714	2182	nviAYCHeatOutCY2	SNVT_temp_p	AYC heat out cmp Y2	-40.00	40.00	°C	30.00	
715	2183	nvoAYCHeatOutCY2	SNVT_temp_p	AYC heat out cmp Y2					

NV Index	SNVT No	SNVT Name	SNVT Type	Description	Min	Max	Unit	Default	Misc
716	2184	nviAYCHeatOutCY3	SNVT_temp_p	AYC heat out cmp Y3	-40.00	40.00	°C	20.00	
717	2185	nvoAYCHeatOutCY3	SNVT_temp_p	AYC heat out cmp Y3					
718	2186	nviAYCHeatOutCY4	SNVT_temp_p	AYC heat out cmp Y4	-40.00	40.00	°C	15.00	
719	2187	nvoAYCHeatOutCY4	SNVT_temp_p	AYC heat out cmp Y4					
720	2196	nviAYCHeatRoomCp	SNVT_temp_p	AYC heat room cmp tmp	0.00	40.00	°C	21.00	
721	2197	nvoAYCHeatRoomCp	SNVT_temp_p	AYC heat room cmp tmp					
722	2198	nviAYCHeatRoomPb	SNVT_temp_p	AYC heat room cmp P-band	1.00	10.00	K	5.00	
723	2199	nvoAYCHeatRoomPb	SNVT_temp_p	AYC heat room cmp P-band					
724	2206	nviAYCHeatNghtCp	SNVT_temp_p	AYC heat night cmp tmp	-10.00	10.00	K	-2.00	
725	2207	nvoAYCHeatNghtCp	SNVT_temp_p	AYC heat night cmp tmp					
726	2236	nviAYC_Heat_P-b	SNVT_temp_p	AYC heat P-band	1.00	40.00	K	15.00	
727	2237	nvoAYC_Heat_P-b	SNVT_temp_p	AYC heat P-band					
728	2238	nviAYC_Heat_I-t	SNVT_time_sec	AYC heat I-time	1	600	s	60	
729	2239	nvoAYC_Heat_I-t	SNVT_time_sec	AYC heat I-time					
730	2242	nviAYCCoolTmpSet	SNVT_temp_p	AYC cool temp set	10.00	80.00	°C	30.00	
731	2243	nvoAYCCoolTmpSet	SNVT_temp_p	AYC cool temp set					
732	2270	nviAYCCoolOutCX1	SNVT_temp_p	AYC cool out cmp X1	-40.00	NV 735	°C	-20.00	
733	2271	nvoAYCCoolOutCX1	SNVT_temp_p	AYC cool out cmp X1					
734	2272	nviAYCCoolOutCX2	SNVT_temp_p	AYC cool out cmp X2	NV 733	NV 737	°C	0.00	
735	2273	nvoAYCCoolOutCX2	SNVT_temp_p	AYC cool out cmp X2					
736	2274	nviAYCCoolOutCX3	SNVT_temp_p	AYC cool out cmp X3	NV 735	NV 739	°C	5.00	
737	2275	nvoAYCCoolOutCX3	SNVT_temp_p	AYC cool out cmp X3					
738	2276	nviAYCCoolOutCX4	SNVT_temp_p	AYC cool out cmp X4	NV 737	40.00	°C	15.00	
739	2277	nvoAYCCoolOutCX4	SNVT_temp_p	AYC cool out cmp X4					
740	2278	nviAYCCoolOutCY1	SNVT_temp_p	AYC cool out cmp Y1	-40.00	40.00	°C	40.00	
741	2279	nvoAYCCoolOutCY1	SNVT_temp_p	AYC cool out cmp Y1					
742	2280	nviAYCCoolOutCY2	SNVT_temp_p	AYC cool out cmp Y2	-40.00	40.00	°C	30.00	
743	2281	nvoAYCCoolOutCY2	SNVT_temp_p	AYC cool out cmp Y2					
744	2282	nviAYCCoolOutCY3	SNVT_temp_p	AYC cool out cmp Y3	-40.00	40.00	°C	20.00	
745	2283	nvoAYCCoolOutCY3	SNVT_temp_p	AYC cool out cmp Y3					
746	2284	nviAYCCoolOutCY4	SNVT_temp_p	AYC cool out cmp Y4	-40.00	40.00	°C	15.00	
747	2285	nvoAYCCoolOutCY4	SNVT_temp_p	AYC cool out cmp Y4					
748	2294	nviAYCCoolRoomCp	SNVT_temp_p	AYC cool room cmp tmp	0.00	40.00	°C	21.00	
749	2295	nvoAYCCoolRoomCp	SNVT_temp_p	AYC cool room cmp tmp					
750	2296	nviAYCCoolRoomPb	SNVT_temp_p	AYC cool room cmp P-band	1.00	10.00	K	5.00	
751	2297	nvoAYCCoolRoomPb	SNVT_temp_p	AYC cool room cmp P-band					
752	2304	nviAYCCoolNghtCp	SNVT_temp_p	AYC cool night cmp tmp	-10.00	10.00	K	-2.00	
753	2305	nvoAYCCoolNghtCp	SNVT_temp_p	AYC cool night cmp tmp					
754	2336	nviAYCCoolDewCpZ	SNVT_temp_p	AYC cool dew point cmp zone	0	5.00	K	2.00	
755	2337	nvoAYCCoolDewCpZ	SNVT_temp_p	AYC cool dew point cmp zone					
756	2338	nviAYCCoolDewCpS	SNVT_lev_percent	AYC cool dew point cmp speed Percent air flow boost of each increased chilled water set point.	0	30.00	%/K	10.00	
757	2339	nvoAYCCoolDewCpS	SNVT_lev_percent	AYC cool dew point cmp speed					
758	2344	nviAYC_Cool_P-b	SNVT_temp_p	AYC cool P-band	1.00	40.00	K	15.00	
759	2345	nvoAYC_Cool_P-b	SNVT_temp_p	AYC cool P-band					
760	2346	nviAYC_Cool_I-t	SNVT_time_sec	AYC cool I-time	1	600	s	60	
761	2347	nvoAYC_Cool_I-t	SNVT_time_sec	AYC cool I-time					
Optimize									
762	2372	nviOptimize_func	SNVT_count	Optimize func	0	1		0	
763	2373	nvoOptimize_func	SNVT_count	Optimize func					

NV Index	SNVT No	SNVT Name	SNVT Type	Description	Min	Max	Unit	Default	Misc
764	2374	nviOptimizeSAsset	SNVT_press_p	Optimize SA press set	20.0	750.0	Pa	0	
765	2375	nvoOptimizeSAsset	SNVT_press_p	Optimize SA press set					
766	2376	nviOptimizeEAsset	SNVT_press_p	Optimize EA press set	20.0	750.0	Pa	0	
767	2377	nvoOptimizeEAsset	SNVT_press_p	Optimize EA press set					
<b>Operation level settings</b>									
768	2684	nviComOperation	SNVT_count	Com operation mode 0=auto, 1=total stop, 2=low speed, 3=high speed, 4=normal stop, 5=extended normal stop.	0	5		0	
769	2685	nvoComOperation	SNVT_count	<b>Com operation mode</b>					
770	4000	nviComOp_Auto	SNVT_switch	Auto Op	0	1		0	
771	4001	nvoComOp_Auto	SNVT_switch	Auto Op					
772	4002	nviComOp_T_Stop	SNVT_switch	Com total stop	0	1		0	
773	4003	nvoComOp_T_Stop	SNVT_switch	Com total stop					
774	4004	nviComOp_LS	SNVT_switch	Com LS	0	1		0	
775	4005	nvoComOp_LS	SNVT_switch	Com LS					
776	4006	nviComOp_HS	SNVT_switch	Com HS	0	1		0	
777	4007	nvoComOp_HS	SNVT_switch	Com HS					
778	4008	nviComOp_N_Stop	SNVT_switch	Com normal stop	0	1		0	
779	4009	nvoComOp_N_Stop	SNVT_switch	Com normal stop					
780	4010	nviComOp_E_Stop	SNVT_switch	Com extended stop	0	1		0	
781	4011	nvoComOp_E_Stop	SNVT_switch	Com extended stop					
<b>Time schedule</b>									
782	2930	nviClock	SNVT_time_stamp	<b>Clock</b> Setting for the unit's internal clock					
783	2931	nvoClock	SNVT_time_stamp	<b>Clock</b>					
784	2962	nviTS_DefaultAct	SNVT_count	<b>Time schedule default action</b> 1=Total stop, 2=Low speed, 3=High speed, 4=Normal stop, 5=Extended normal stop	1	5		2	
785	2963	nvoTS_DefaultAct	SNVT_count	<b>Time schedule default action</b>					
<b>Internal</b>									
786	5000	nvoMajorVerLon	SNVT_count	<b>Major version of SW in GW</b> Major version of software in LonWorks gateway.					
787	5001	nvoMinorVerLon	SNVT_count	<b>Minor version of SW in GW</b> Minor version of software in LonWorks gateway.					
788	1	nvoObjStatus	SNVT_obj_status	<b>Response status variable to obj_request</b>					
789	2	nviObjRequest	SNVT_obj_request	<b>Request variable for status of obj_status</b>					
790		nciAutoSendTime	SNVT_time_sec	<b>Autoupdate of all netvars</b> This variable defines the time it takes for all the parameters to be automatically updated on the network. 0 = The Autosend function is disabled.					
791		nciSndHrtBt	SNVT_time_sec	<b>Send Heartbeat Time</b> 0 = The send heartbeat function is disabled.					
792		nciRcvHrtBt	SNVT_time_sec	<b>Receive Heartbeat Time</b> 0 = The receive heartbeat function is disabled.					
793		nciMinOutTm	SNVT_time_sec	<b>Min Time Between updates</b> Minimum period of time between automatic network variable output transmissons. 0 = The min time between function is disabled.					
794		nciLocation	SNVT_str_asc	<b>Location</b>					
795		nciSwitchCfg	SNVT_count	<b>SNVT_switch inp 0=as spec,&gt;=1 value OR state</b>					